

Machine Id KAESER CSD 75 4284146 (S/N 1024) Component Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

WEAR	

All component wear rates are normal.

CONTAMINATION


There is a moderate amount of particulates present in the oil.

.....

FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		KCPA010217	KCPA003200	KCP53123
Sample Date		Client Info		22 Jan 2024	15 Jun 2023	03 Jan 2023
Machine Age	hrs	Client Info		103669	98356	94500
Oil Age	hrs	Client Info		0	0	3614
Filter Age	hrs	Client Info		0	0	3614
Oil Changed		Client Info		N/A	N/A	Changed
Filter Changed		Client Info		Changed	Changed	Changed
Sample Status				ATTENTION	ATTENTION	ABNORMAL
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	12	17	10
Tin	ppm	ASTM D5185m	>10	<1	<1	<1
Vanadium	ppm	ASTM D5185m		<1	0	0
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Potassium	ppm	ASTM D5185m	>20	0	1	0
Water	%	ASTM D6304	>0.05	0.013	0.006	0.001
ppm Water	ppm	ASTM D6304	>500	134	66.5	13.4
Particles >4µm		ASTM D7647		6201	3024	18176
Particles >6µm		ASTM D7647	>1300	— 1906	1189	<u> </u>
Particles >14µm		ASTM D7647	>80	— 151	117	<u> </u>
Particles >21µm		ASTM D7647	>20	934	26	A 31
Particles >38µm		ASTM D7647	>4	1	0	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	e 20/18/14	9/17/14	<u> </u>
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Codium	0000			0		0
Sodium	ppm	ASTM D5185m	0	0	1	0
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	<1	0
Molybdenum	ppm	ASTM D5185m	0	0	<1	0
Manganese	ppm	ASTM D5185m	100	<1	<1	0
Magnesium	ppm	ASTM D5185m	100	0	7	0
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	<1	4	24
Zinc	ppm	ASTM D5185m	0	0	4	2
Sulfur	ppm	ASTM D5185m	23500	14681	19216	19615
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.55	0.48	0.48
Visc @ 40°C	cSt	ASTM D445	45	52.81	50.6	52.5



AZZ GALVANIZING CO Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA010217 4400 E 61ST AVE Sample No. Received : 31 Jan 2024 Lab Number COMMERCE CITY, CO : 06075777 Tested :06 Feb 2024 Unique Number : 10857868 : 06 Feb 2024 - Jonathan Hester US 80022 Diagnosed Test Package : IND 2 (Additional Tests: KF, PrtCount) Contact: TINA HERMAN Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. tinaherman@azz.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: F: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Ġ

Contact/Location: TINA HERMAN - AZZCOM