WEAR CONTAMINATION FLUID CONDITION

NORMAL NORMAL NORMAL

ÜLTRA COOLANT

CBV907201 - CARVER PUMP CO

Component Compressor

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		UCH06075968		
	Sample Date		Client Info		19 Jan 2024		
	Machine Age	hrs	Client Info		2555		
	Oil Age	hrs	Client Info		2555		
	Filter Age	hrs	Client Info		0		
	Oil Changed		Client Info		Not Changd		
	Filter Changed		Client Info		Changed		
	Sample Status				NORMAL		
WEAR	Iron	ppm	ASTM D5185m	>50	0		
All component wear rates are normal.	Chromium	ppm	ASTM D5185m		0		
	Nickel	ppm	ASTM D5185m	, , ,	<1		
	Titanium	ppm	ASTM D5185m		0		
	Silver	ppm	ASTM D5185m		0		
	Aluminum	ppm	ASTM D5185m	>25	<1		
	Lead	ppm	ASTM D5185m		1		
	Copper	ppm	ASTM D5185m		<1		
	Tin	ppm	ASTM D5185m		<1		
	Vanadium	ppm	ASTM D5185m		0		
	White Metal	scalar	*Visual	NONE	LIGHT		
	Yellow Metal	scalar	*Visual	NONE	NONE		
CONTAMINATION There is no indication of any contamination in the oil.	Silicon	ppm	ASTM D5185m		2		
	Potassium	ppm	ASTM D5185m		4		
	Water		WC Method	>0.1	NEG		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	LIGHT		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
FLUID CONDITION	Sodium	ppm	ASTM D5185m		14		
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m	0	0		
	Barium	ppm	ASTM D5185m	500	737		
	Molybdenum	ppm	ASTM D5185m	0	0		
	Manganese	ppm	ASTM D5185m		<1		
	Magnesium	ppm	ASTM D5185m	0	2		
	Calcium	ppm	ASTM D5185m	0	2		
	Phosphorus	ppm	ASTM D5185m	20	2		
	Zinc	ppm	ASTM D5185m	0	0		
			ACTM DE10E	000	202		
	Sulfur	ppm	ASTM D5185m	200	323		
	Sulfur Acid Number (AN)	mg KOH/g	ASTM D5185m	200	0.086		







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: 10858059 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCH06075968 Recieved : 31 Jan 2024 : 06075968 Diagnosed : 02 Feb 2024

Diagnostician : Don Baldridge

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

A-L-L EQUIPMENT INC

204 38TH ST MOLINE, IL US 61265

Contact: KEVIN DESPOT kevind@a-l-lequipment.com

T: (815)877-7000 F: (309)762-9950