
**WEAR CONTAMINATION FLUID CONDITION**  **ATTENTION ABNORMAL NORMAL** 

**NOT GIVEN** 

## ATLAS COPCO AIF060613 - TULSA CEMENT PLANT AIR 3

Component Compressor

<u></u>							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
We advise that you check all areas where dirt can enter the system. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.	Sample Number		Client Info		UCH06077013	UCH05948146	
	Sample Date		Client Info		26 Jan 2024	06 Sep 2023	
	Machine Age	hrs	Client Info		109961	108678	
	Oil Age	hrs	Client Info		8000	0	
	Filter Age	hrs	Client Info		0	0	
	Oil Changed		Client Info		Changed	N/A	
	Filter Changed		Client Info		Changed	N/A	
	Sample Status				ABNORMAL	ABNORMAL	
WEAR	Iron	ppm	ASTM D5185m	>50	<b>▲</b> 58	46	
	Chromium	ppm	ASTM D5185m		<1	<1	
The iron level is abnormal. All other component wear rates are normal.	Nickel	ppm	ASTM D5185m		<1	<1	
	Titanium	ppm	ASTM D5185m		<1	<1	
	Silver	ppm	ASTM D5185m		0	0	
	Aluminum	ppm	ASTM D5185m	>15	<b>▲</b> 13	<b>▲</b> 13	
	Lead	ppm	ASTM D5185m		<1	0	
	Copper	ppm	ASTM D5185m		11	9	
	Tin	ppm	ASTM D5185m		2	6	
	Vanadium	ppm	ASTM D5185m		0	0	
	White Metal	scalar	*Visual	NONE	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
OONT A MINIA TION							
CONTAMINATION	Silicon	ppm	ASTM D5185m		<b>▲</b> 38	<u>4</u> 7	
Elemental levels of silicon (Si) and aluminum (Al) indicate aluminasilicate (coarse dirt) ingress.	Potassium	ppm	ASTM D5185m		11	13	
	Water		WC Method		NEG	NEG	
	Silt	scalar	*Visual	NONE	NONE	MODER	
	Debris	scalar	*Visual	NONE	NONE	NONE	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
	Appearance	scalar	*Visual	NORML	NORML	NORML	
	Odor	scalar	*Visual	NORML	NORML	NORML	
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	
FLUID CONDITION	Sodium	ppm	ASTM D5185m		16	18	
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m		0	0	
	Barium	ppm	ASTM D5185m		469	593	
suitable for further service.	Molybdenum	ppm	ASTM D5185m		0	0	
suitable for further service.	Molybuenum				4	<1	
suitable for further service.	Manganese	ppm	ASTM D5185m		<1	< 1	
suitable for further service.	•	ppm ppm	ASTM D5185m ASTM D5185m		7	7	
suitable for further service.	Manganese						
suitable for further service.	Manganese Magnesium	ppm	ASTM D5185m		7	7	
suitable for further service.	Manganese Magnesium Calcium	ppm	ASTM D5185m ASTM D5185m		7 324	7 404	
suitable for further service.	Manganese Magnesium Calcium Phosphorus	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m		7 324 155	7 404 43	
suitable for further service.	Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m		7 324 155 12	7 404 43 0	







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: UCH06077013 : 06077013 : 10859104 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved : 01 Feb 2024 : 02 Feb 2024 Diagnosed : Don Baldridge Diagnostician

**GREEN COUNTY COMPRESSOR SERVICE** 11974 E 530 RD

CLAREMORE, OK US 74019 Contact: ASHLEY PIGUET ashley@gccs.us.com

T: (918)906-6343

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)