



OIL ANALYSIS REPORT

WEAR	ABNORMAL
CONTAMINATION	SEVERE
FLUID CONDITION	NORMAL

Machine Id
BT-FOR-A7 (S/N TANK FT7 AGITATOR)

Component
Gearbox

Fluid
SHELL OMALA S2 GX 220 (--- GAL)

RECOMMENDATION

Filter oil if possible using B6=75 filter media or better. If filtration is not possible consider changing oil. No other action required at this time. Resample at next normal interval.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PLS0000718	PLS0000784	PLS0000562
Sample Date		Client Info		31 Jan 2024	25 Oct 2023	09 Aug 2023
Machine Age	mths	Client Info		3	0	0
Oil Age	mths	Client Info		0	1	0
Filter Age	mths	Client Info		0	0	0
Oil Changed		Client Info		N/A	Changed	N/A
Filter Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	SEVERE	SEVERE

WEAR

Iron wear particles are elevated from previous samples. This could indicate accelerated wear.

PQ	UOM	Method	Limit/Abn	Current	History1	History2
Iron	ppm	ASTM D5185m	>200	▲ 84	56	48
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	0	0
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	0	0	<1
Tin	ppm	ASTM D5185m	>25	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION











Particle contamination is highly elevated. Filtration can help extend machine life.

Silicon	ppm	ASTM D5185m	>50	3	1	2
Potassium	ppm	ASTM D5185m	>20	0	0	<1
Water		WC Method	>0.2	NEG	NEG	NEG
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624		3.0	3.0	2.9
Sulfation	Abs/.1mm	*ASTM D7415		12.1	12.1	11.8
Particles >4µm		ASTM D7647	>20000	● 199674	● 183672	▲ 158644
Particles >6µm		ASTM D7647	>5000	● 146589	● 81053	● 75548
Particles >14µm		ASTM D7647	>640	● 29815	▲ 2529	● 6914
Particles >21µm		ASTM D7647	>160	● 6012	▲ 244	● 1363
Particles >38µm		ASTM D7647	>40	33	2	23
Particles >71µm		ASTM D7647	>10	1	0	0
Oil Cleanliness		ISO 4406 (c)	>21/19/16	● 25/24/22	● 25/24/19	● 24/23/20
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG

FLUID CONDITION

Fluid health is acceptable for continued use provided that contamination can be brought under control.

Sodium	ppm	ASTM D5185m		0	1	0
Boron	ppm	ASTM D5185m	6.2	0	0	0
Barium	ppm	ASTM D5185m	0.0	<1	0	<1
Molybdenum	ppm	ASTM D5185m	0	0	0	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	0	1	0	4
Calcium	ppm	ASTM D5185m	0.0	5	0	5
Phosphorus	ppm	ASTM D5185m	290	303	218	273
Zinc	ppm	ASTM D5185m	3.8	15	0	14
Sulfur	ppm	ASTM D5185m	8167	9749	8641	10188
Oxidation	Abs/.1mm	*ASTM D7414		2.9	3.0	2.8
Acid Number (AN)	mg KOH/g	ASTM D8045		0.48	0.44	0.45
Visc @ 40°C	cSt	ASTM D445	220	215	210	210



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : PLS0000718

Lab Number : 06077613

Unique Number : 10859704

Test Package : IND 2 (Additional Tests: FT-IR, PQ, PrtCount)

Received : 01 Feb 2024

Tested : 02 Feb 2024

Diagnosed : 09 Feb 2024 - Mike Johnson

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

HEXION - BAYTOWN PLANT

8450 WEST BAY RD

BAYTOWN, TX

US 77520

Contact: BILL MINER

bill.miner@momentive.com

T:

F: