

ALL ADVANTAGE 46 [151142] Machine Id CBV242732 - KOPPER Component Compressor

					<u> </u>		
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		UCH06082633	UCH05853271	UCH04533508
	Sample Date		Client Info		29 Jan 2024	02 May 2023	13 Aug 2018
	Machine Age	hrs	Client Info		39384	35848	16985
	Oil Age	hrs	Client Info		4000	0	0
	Filter Age	hrs	Client Info		2000	0	0
	Oil Changed		Client Info		Changed	Not Changd	Changed
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				NORMAL	NORMAL	NORMAL
WEAR	Iron	ppm	ASTM D5185m	>50	0	0	0
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>10	<1	0	0
	Nickel	ppm	ASTM D5185m		0	0	0
	Titanium	ppm	ASTM D5185m		0	0	0
	Silver	ppm	ASTM D5185m		0	0	0
	Aluminum	ppm	ASTM D5185m	>25	2	0	<1
	Lead	ppm	ASTM D5185m	>25	0	0	<1
	Copper	ppm	ASTM D5185m	>50	0	0	<1
	Tin	ppm	ASTM D5185m	>15	0	<1	0
	Vanadium	ppm	ASTM D5185m		0	0	0
	White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
CONTAMINATION There is no indication of any contamination in the oil.	Silicon	ppm	ASTM D5185m	>25	0	2	2
	Potassium	ppm	ASTM D5185m	>20	0	<1	1
	Water		WC Method	>0.1	NEG	NEG	NEG
	Silt	scalar	*Visual	NONE	NONE	NONE	NONE
	Debris	scalar	*Visual	NONE	NONE	MODER	NONE
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
	Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
	Odor	scalar	*Visual	NORML	NORML	NORML	NORML
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
FLUID CONDITION	Sodium	ppm	ASTM D5185m		0	6	2
The AN level is acceptable for this fluid. The condition of the oil is	Boron	ppm	ASTM D5185m		0	0	<1
suitable for further service.	Barium	ppm	ASTM D5185m		6	17	7
	Molybdenum	ppm	ASTM D5185m		0	0	0
	Manganese	ppm	ASTM D5185m		0	<1	<1
	Magnesium	ppm	ASTM D5185m		0	14	<1
	Calcium	ppm	ASTM D5185m		0	14	0
	Phosphorus	ppm	ASTM D5185m		385	295	177
	Zinc	ppm	ASTM D5185m		17	117	11

Sulfur

ppm ASTM D5185m

ASTM D445

Acid Number (AN) mg KOH/g ASTM D8045

Visc @ 40°C cSt

Contact/Location: KEVIN DESPOT - UCALLMOL

114

0.37

45.3

444


0.30

45.1

90

0.300

46.65



Sample No. : UCH06082633 Received :07 Feb 2024 204 38TH ST Lab Number : 06082633 :08 Feb 2024 MOLINE, IL Tested Unique Number : 10870078 : 09 Feb 2024 - Don Baldridge US 61265 Diagnosed Test Package : IND 2 Contact: KEVIN DESPOT Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. kevind@a-l-lequipment.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (815)877-7000 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (309)762-9950

õ

ΞJ