

FG-460 [WO-7678] Machine Id KAESER 1468 - PHASE THREE BREWING Component Compressor

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		UCH06084887		
	Sample Date		Client Info		26 Jan 2024		
	Machine Age	hrs	Client Info		3911		
	Oil Age	hrs	Client Info	_	1722		
	Filter Age	hrs	Client Info		1722		
	Oil Changed		Client Info		Changed		
	Filter Changed		Client Info		Changed		
	Sample Status				NORMAL		
WEAR	Iron	ppm	ASTM D5185m	>50	7		
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>10	0		
	Nickel	ppm	ASTM D5185m	>3	0		
	Titanium	ppm	ASTM D5185m	>3	0		
	Silver	ppm	ASTM D5185m	>2	0		
	Aluminum	ppm	ASTM D5185m	>10	8		
	Lead	ppm	ASTM D5185m	>10	<1		
	Copper	ppm	ASTM D5185m	>50	4		
	Tin	ppm	ASTM D5185m	>10	0		
	Vanadium	ppm	ASTM D5185m		0		
	White Metal	scalar	*Visual	NONE	LIGHT		
	Yellow Metal	scalar	*Visual	NONE	NONE		
CONTAMINATION There is no indication of any contamination in the oil.	Silicon		ASTM D5185m	> 25	0		
	Potassium	ppm ppm	ASTM D5185m		0		
	Water	ррш	WC Method		NEG		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water		*Visual	>0.05	NEG		
FLUID CONDITION	Sodium	ppm	ASTM D5185m		4		
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m		0		
	Barium	ppm	ASTM D5185m		0		
	Molybdenum	ppm	ASTM D5185m		0		
	Manganese	ppm	ASTM D5185m		<1		
	Magnesium	ppm	ASTM D5185m		0		
	-						
	Calcium	ppm	ASTM D5185m		0		
	Calcium Phosphorus	ppm ppm	ASTM D5185m	500	302		
	Calcium			500			


Acid Number (AN) mg KOH/g ASTM D8045 1.5

Visc @ 40°C cSt ASTM D445 46

Contact/Location: MICHAEL FERRIS - UCDELDOW

0.75

45.5



DELTA INDUSTRIES - DOWNERS GROVE Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. : UCH06084887 Received : 09 Feb 2024 2201 CURTISS STREET Lab Number : 06084887 : 12 Feb 2024 DOWNERS GROVE, IL Tested Unique Number : 10872332 : 12 Feb 2024 - Don Baldridge US 60515 Diagnosed Test Package : IND 2 Contact: MICHAEL FERRIS Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (630)960-3931

Contact/Location: MICHAEL FERRIS - UCDELDOW