



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Machine Id
LGS00180
Component
Middle Biogas Engine
Fluid
CITGO PACEMAKER GAS ENGINE LFG LA 40 (--- GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0803454	WC0803456	WC0803457
Sample Date		Client Info		05 Feb 2024	30 Jan 2024	15 Jan 2024
Machine Age	hrs	Client Info		61379	61379	61083
Oil Age	hrs	Client Info		247	247	402
Filter Age	hrs	Client Info		698	698	402
Oil Changed		Client Info		N/A	N/A	N/A
Filter Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL

WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>45	0	4	3
Chromium	ppm	ASTM D5185m	>2	0	<1	0
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	2	2
Lead	ppm	ASTM D5185m	>5	1	0	0
Copper	ppm	ASTM D5185m	>14	<1	<1	1
Tin	ppm	ASTM D5185m	>13	1	2	4
Vanadium	ppm	ASTM D5185m		0	0	<1
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION












There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>200	78	115	172
Potassium	ppm	ASTM D5185m	>20	<1	1	0
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
Water		WC Method	>0.1	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	*ASTM D7844		0.1	0	0
Nitration	Abs/cm	*ASTM D7624	>20	10.2	3.5	3.7
Sulfation	Abs/.1mm	*ASTM D7415	>30	20.1	16.1	17.2
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		<1	0	1
Boron	ppm	ASTM D5185m		2	1	<1
Barium	ppm	ASTM D5185m		0	5	0
Molybdenum	ppm	ASTM D5185m		2	2	3
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		20	35	28
Calcium	ppm	ASTM D5185m		1308	1390	1494
Phosphorus	ppm	ASTM D5185m		232	333	317
Zinc	ppm	ASTM D5185m		333	368	378
Sulfur	ppm	ASTM D5185m		2598	3142	3223
Oxidation	Abs/.1mm	*ASTM D7414	>25	17.2	7.2	7.9
Acid Number (AN)	mg KOH/g	ASTM D8045	1.16	0.69	0.65	0.75
Base Number (BN)	mg KOH/g	ASTM D2896	5	3.33	3.52	3.89
Visc @ 100°C	cSt	ASTM D445	13.5	12.8	12.8	12.9



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0803454
Lab Number : 06084976
Unique Number : 10872421
Test Package : MOB 2
Received : 09 Feb 2024
Tested : 12 Feb 2024
Diagnosed : 12 Feb 2024 - Don Baldrige

BLACK OAK
 5054 HWY HH
 HARTVILLE, MO
 US 65667

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact: CHIP MATHEWS
 chip.matthews@cubedistrictenergy.com
 T:
 F: