

## Machine Id 91016 Component Front Front Left Genset Fluid MOBIL 1 FORMULA 10W30 (2 QTS)

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		WC0824086		
	Sample Date		Client Info		06 Feb 2024		
	Machine Age	hrs	Client Info		2156		
	Oil Age	hrs	Client Info		200		
	Filter Age	hrs	Client Info		200		
	Oil Changed		Client Info		N/A		
	Filter Changed		Client Info		N/A		
	Sample Status				ATTENTION		
WEAR	Iron	ppm	ASTM D5185m		4		
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>4	<1		
	Nickel	ppm	ASTM D5185m	>2	<1		
	Titanium	ppm	ASTM D5185m		<1		
	Silver	ppm	ASTM D5185m		0		
	Aluminum	ppm	ASTM D5185m	>12	2		
	Lead	ppm	ASTM D5185m	>17	<1		
	Copper	ppm	ASTM D5185m	>70	1		
	Tin	ppm	ASTM D5185m	>15	<1		
	Vanadium	ppm	ASTM D5185m		0		
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
CONTAMINATION	Silicon	ppm	ASTM D5185m	>25	23		
	Potassium	ppm	ASTM D5185m		2		
There is no indication of any contamination in the oil.	Fuel	le le	WC Method		_ <1.0		
	Water		WC Method		NEG		
	Glycol		WC Method		NEG		
	Soot %	%	*ASTM D7844		0		
	Nitration	Abs/cm	*ASTM D7624	>20	6.9		
	Sulfation	Abs/.1mm	*ASTM D7415		17.2		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
FLUID CONDITION	Sodium	ppm	ASTM D5185m		0		
	Boron	ppm	ASTM D5185m		49		
The oil viscosity is higher than normal. The BN result indicates that there is suitable alkalinity remaining in the oil. Confirm oil type.	Barium	ppm	ASTM D5185m		0		
	Molybdenum	ppm	ASTM D5185m		53		
	Manganese	ppm	ASTM D5185m		<1		
	Magnesium	ppm	ASTM D5185m		120		
	Calcium		ASTM D5185m		2264		
	Phosphorus	ppm	ASTM D5185m		955		
		ppm					
	Zinc	ppm	ASTM D5185m		1182		
	Sulfur	ppm	ASTM D5185m	. 05	3662		
	Oxidation	Abs/.1mm	*ASTM D7414	>20	12.2		
	Base Number (BN)	mg KOH/g	ASTM D2896	10.0	7.5		

Visc @ 100°C cSt ASTM D445 10.0

**15.2** 



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 **ATEL BUS & TRUCK** Sample No. : WC0824086 12120 CONWAY RD Received : 09 Feb 2024 : 12 Feb 2024 Lab Number : 06085299 BELTSVILLE, MD Tested Unique Number : 10872744 : 12 Feb 2024 - Don Baldridge US 20705 Diagnosed Test Package : MOB 1 (Additional Tests: TBN) Contact: OSCAR ROMERO Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. oromero@atelbus.com \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Т: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F:

Ċ

s;