



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	ABNORMAL
FLUID CONDITION	NORMAL

Area
Co-Gen - Utilities
 Machine Id
32-1800 GE TURBINE

Component
Steam Turbine
 Fluid
Mobil DTE-832 ISO32 TURBINE OIL (1300 GAL)

RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PE0001532	PE0001468	PE0000989
Sample Date		Client Info		06 Feb 2024	21 Dec 2023	25 Jul 2023
Machine Age	hrs	Client Info		10	10	10
Oil Age	hrs	Client Info		10	10	10
Filter Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Filter Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	ATTENTION

WEAR

All component wear rates are normal.

PQ	UOM	Method	Limit/Abn	Current	History1	History2
Iron	ppm	ASTM D5185m	>15	0	0	0
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m		0	0	3
Copper	ppm	ASTM D5185m	>5	<1	0	<1
Tin	ppm	ASTM D5185m	>5	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	<1
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION











There is a high amount of particulates present in the oil.

Silicon	ppm	ASTM D5185m	>15	0	0	<1
Potassium	ppm	ASTM D5185m	>20	0	0	<1
Water		WC Method	>0.03	NEG	NEG	NEG
Particles >4µm		ASTM D7647	>1300	▲ 2336	948	▲ 1689
Particles >6µm		ASTM D7647	>320	▲ 681	202	▲ 363
Particles >14µm		ASTM D7647	>80	▲ 83	26	25
Particles >21µm		ASTM D7647	>20	▲ 37	13	9
Particles >38µm		ASTM D7647	>4	4	2	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>17/15/13	▲ 18/17/14	17/15/12	▲ 18/16/12
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.03	NEG	NEG	NEG

FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		1	1	<1
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	0	<1
Calcium	ppm	ASTM D5185m		1	0	0
Phosphorus	ppm	ASTM D5185m		969	1055	1029
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		21	0	7
Acid Number (AN)	mg KOH/g	ASTM D8045		0.17	0.15	0.20
Visc @ 40°C	cSt	ASTM D445		30.8	30.6	30.7



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PE0001532 **Received** : 09 Feb 2024
Lab Number : 06085349 **Tested** : 12 Feb 2024
Unique Number : 10872794 **Diagnosed** : 12 Feb 2024 - Doug Bogart
Test Package : PLANT (Additional Tests: ICP, KV40, PQ, PrtCount, SCREEN)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

MCKINLEY PAPER COMPANY
 1902 MARINE DR
 PORT ANGELES, WA
 US 98363
 Contact: CHAD GALLAUHER
 chad.gallauher@biopappel.com
 T: (360)457-4474
 F: