



WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Machine Id
DETROIT SYNERGY PGE
Component
Port Genset
Fluid
CHEVRON DELO 710 LE (5 GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		MW0060556	MW0060514	MW0014574
Sample Date		Client Info		19 Jan 2024	07 Jul 2023	02 Nov 2022
Machine Age	hrs	Client Info		1709	0	0
Oil Age	hrs	Client Info		0	0	0
Filter Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Changed	Changed	Changed
Filter Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL

WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>50	16	16	14
Chromium	ppm	ASTM D5185m	>4	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	<1	0	0
Titanium	ppm	ASTM D5185m		<1	<1	<1
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>12	2	2	2
Lead	ppm	ASTM D5185m	>17	2	<1	<1
Copper	ppm	ASTM D5185m	>70	2	3	2
Tin	ppm	ASTM D5185m	>15	1	1	3
Vanadium	ppm	ASTM D5185m		0	0	0
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION







There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>25	6	5	3
Potassium	ppm	ASTM D5185m	>20	1	2	0
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
Water		WC Method	>0.1	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	*ASTM D7844		0.1	0.5	0.1
Nitration	Abs/cm	*ASTM D7624	>20	9.4	7.8	8.6
Sulfation	Abs/.1mm	*ASTM D7415	>30	16.4	19.8	16.1
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		0	3	1
Boron	ppm	ASTM D5185m		51	52	44
Barium	ppm	ASTM D5185m		14	0	0
Molybdenum	ppm	ASTM D5185m		50	46	44
Manganese	ppm	ASTM D5185m		1	<1	<1
Magnesium	ppm	ASTM D5185m		45	22	22
Calcium	ppm	ASTM D5185m		3198	3977	3455
Phosphorus	ppm	ASTM D5185m		69	21	15
Zinc	ppm	ASTM D5185m	10	42	20	16
Sulfur	ppm	ASTM D5185m		2747	3233	2505
Oxidation	Abs/.1mm	*ASTM D7414	>25	11.8	13.5	9.2
Base Number (BN)	mg KOH/g	ASTM D2896	9.2	6.7	8.7	8
Visc @ 100°C	cSt	ASTM D445	15.5	14.4	13.9	14.0



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : MW0060556

Lab Number : 06085732

Unique Number : 10873177

Test Package : MAR 2

Received : 12 Feb 2024

Tested : 12 Feb 2024

Diagnosed : 13 Feb 2024 - Don Baldrige

ERGON MARINE

100 LEE STREET

VICKSBURG, MS

US 39180

Contact: JOHNNY GERACHE

johnny.gerache@ergon.com

T: (601)636-6552

F: (601)636-6173

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)