



TRAAP

Texas Refinery Advanced Analysis Program

# OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Machine Id  
**MACK GU713 84 (S/N 1M2AX09C9HM030241)**

Component  
**Diesel Engine**

Fluid  
**TRC MOLY XL PRO-SPEC IV XP 15W40 (40 QTS)**

## RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>TR06087608</b>	TR06039560	TR06000044
Sample Date		Client Info		<b>01 Feb 2024</b>	14 Dec 2023	02 Nov 2023
Machine Age	hrs	Client Info		<b>2710</b>	2490	2253
Oil Age	hrs	Client Info		<b>720</b>	500	280
Filter Age	hrs	Client Info		<b>720</b>	500	280
Oil Changed		Client Info		<b>Changed</b>	Not Changd	Not Changd
Filter Changed		Client Info		<b>Changed</b>	Not Changd	Not Changd
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

## WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>120	<b>47</b>	34	25
Chromium	ppm	ASTM D5185m	>20	<b>1</b>	1	<1
Nickel	ppm	ASTM D5185m	>5	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m	>2	<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m	>2	<b>&lt;1</b>	<1	0
Aluminum	ppm	ASTM D5185m	>20	<b>33</b>	28	21
Lead	ppm	ASTM D5185m	>40	<b>2</b>	1	<1
Copper	ppm	ASTM D5185m	>330	<b>2</b>	1	<1
Tin	ppm	ASTM D5185m	>15	<b>&lt;1</b>	1	<1
Vanadium	ppm	ASTM D5185m		<b>0</b>	<1	0
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE

## CONTAMINATION












Elevated aluminum (Al) and/or lead (Pb) and potassium (K) levels in your metals analysis are likely a result of solder flux release into the lubricant and is common on new equipment/components. There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>25	<b>8</b>	8	6
Potassium	ppm	ASTM D5185m	>20	<b>71</b>	68	54
Fuel		WC Method	>3.0	<b>&lt;1.0</b>	<1.0	<1.0
Water		WC Method	>0.2	<b>NEG</b>	NEG	NEG
Glycol		WC Method		<b>NEG</b>	NEG	NEG
Soot %	%	*ASTM D7844	>4	<b>0.9</b>	0.7	0.4
Nitration	Abs/cm	*ASTM D7624	>20	<b>12.6</b>	11.4	9.7
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>27.0</b>	23.8	19.8
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	<b>NEG</b>	NEG	NEG

## FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		<b>&lt;1</b>	2	2
Boron	ppm	ASTM D5185m		<b>0</b>	4	0
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>134</b>	115	112
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>17</b>	21	17
Calcium	ppm	ASTM D5185m		<b>3769</b>	3708	3616
Phosphorus	ppm	ASTM D5185m		<b>846</b>	917	875
Zinc	ppm	ASTM D5185m		<b>1107</b>	1104	1112
Sulfur	ppm	ASTM D5185m		<b>3923</b>	4118	4199
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>15.6</b>	13.6	11.1
Base Number (BN)	mg KOH/g	ASTM D2896		<b>10.16</b>	12.03	13.15
Visc @ 100°C	cSt	ASTM D445		<b>15.4</b>	15.2	15.2



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TR06087608  
**Lab Number** : 06087608  
**Unique Number** : 10875053  
**Test Package** : MOB 2

**Received** : 13 Feb 2024  
**Tested** : 14 Feb 2024  
**Diagnosed** : 14 Feb 2024 - Wes Davis

**ANDREWS CONSTRUCTION COMPANY**  
 PO BOX 720  
 CAMPTON, NH  
 US 03223-0720  
 Contact: DON PERCY

To discuss this sample report, contact Customer Service at 1-800-827-0711.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: