WEAR CONTAMINATION **FLUID CONDITION**


NORMAL NORMAL NORMAL


(YA149648)


Machine Id **3849C**


Component Natural Gas Engine


RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
	Sample Number		Client Info		GFL0089998	GFL0080596	GFL006685
Resample at the next service interval to monitor.	Sample Date		Client Info		03 Feb 2024	20 Jul 2023	02 Jun 2020
	Machine Age	hrs	Client Info		13219	6367	6367
	Oil Age	hrs	Client Info		1800	6367	6367
	Filter Age	hrs	Client Info		1800	0	0
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				NORMAL	NORMAL	NORMAL
VEAR	Iron	nnm	ASTM D5185m	<u>>50</u>	14	11	11
VEAN	Chromium	ppm	ASTM D5185m		<1	<1	<1
All component wear rates are normal.	Nickel	ppm	ASTM D5185m		0	0	0
	Titanium	ppm	ASTM D5185m	>2	0	0	0
	Silver	ppm	ASTM D5185m	. 2	0	0	0
	Aluminum	ppm	ASTM D5185m		1	2	2
	Lead	ppm	ASTM D5185m		0	<1	<1
	Copper	ppm	ASTM D5185m		<1	<1	<1
	Tin	ppm	ASTM D5185m		0	0	0
	Vanadium	ppm	ASTM D5185m	>4	0	0	0
	White Metal	ppm scalar	*Visual	NONE	NONE	LIGHT	NONE
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
<u></u>			visuai		·····	INOINL	INOINL
CONTAMINATION	Silicon	ppm	ASTM D5185m	>+100	5	5	5
	Potassium	ppm	ASTM D5185m	>20	4	8	<1
There is no indication of any contamination in the oil.	Water		WC Method	>0.1	NEG	NEG	NEG
	Soot %	%	*ASTM D7844		0	0	0.1
	Nitration	Abs/cm	*ASTM D7624	>20	10.6	11.5	11.1
	Sulfation	Abs/.1mm	*ASTM D7415	>30	19.7	23.8	22.0
	Silt	scalar	*Visual	NONE	NONE	NONE	NONE
	Debris	scalar	*Visual	NONE	NONE	NONE	NONE
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
	Appearance	scalar	*Visual	NORML	NORML	NORML	NORM
	Odor	scalar	*Visual	NORML	NORML	NORML	NORM
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
FLUID CONDITION	Sodium	ppm	ASTM D5185m		3	17	7
	Boron	ppm	ASTM D5185m	50	22	11	14
The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.	Barium	ppm	ASTM D5185m	5	8	0	0
	Molybdenum	ppm	ASTM D5185m	50	51	59	56
	Manganese	ppm	ASTM D5185m	0	0	<1	<1
	Magnesium	ppm	ASTM D5185m	560	502	648	640
	Calcium	ppm	ASTM D5185m		1396	1798	1704
	Phosphorus	ppm	ASTM D5185m		647	800	794
	Zinc	ppm	ASTM D5185m		877	1093	1086
	Sulfur	ppm	ASTM D5185m	2040	2295	3121	3123
	Oxidation	Abs/.1mm	*ASTM D7414		16.6	19.8	18.3
	Base Number (BN)				5.8	4.5	5.7
	Dase Mulliper (DIN)	my Normy	AO 1101 D2030	10.2	5.0	4.5	0.7
















Certificate L2367

Report Id: GFL018 [WUSCAR] 06088521 (Generated: 02/15/2024 10:33:29) Rev: 1

Laboratory Sample No.

Lab Number : 06088521

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : GFL0089998

Unique Number: 10875966

Received **Tested** Diagnosed Test Package : FLEET

: 15 Feb 2024 : 15 Feb 2024 - Wes Davis

: 14 Feb 2024

GFL Environmental - 018 - Fayetteville 4621 Marracco Drive Hope Mills, NC US 28348

Contact: Robert Carter robert.carter@gflenv.com T: (910)596-1170

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Submitted By: CHRIS HALL

F: