



# FUEL REPORT

CORROSION	NORMAL
CONTAMINANTS	NORMAL
FUEL CONDITION	NORMAL

Area  
**[PM02H2635139]**  
 Machine Id  
**199638 - DAY TANK**  
 Component  
**Diesel Fuel**  
 Fluid  
**{not provided} (--- GAL)**

## RECOMMENDATION

All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>DC0029142</b>	---	---
Sample Date		Client Info		<b>08 Feb 2024</b>	---	---
Machine Age	hrs	Client Info		<b>1019</b>	---	---
Sample Status				<b>NORMAL</b>	---	---

## CORROSION

All metal levels are normal indicating no corrosion in the system.

Aluminum	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Nickel	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Lead	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Vanadium	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Iron	ppm	ASTM D5185m	<0.1	<b>&lt;1</b>	---	---

## CONTAMINANTS




The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel.

Silicon	ppm	ASTM D5185m	<1.0	<b>0</b>	---	---
Sodium	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Potassium	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Water	%	ASTM D6304	<0.05	<b>0.003</b>	---	---
ppm Water	ppm	ASTM D6304	<500	<b>39</b>	---	---
% Gasoline	%	*In-House	<0.50	<b>0.0</b>	---	---
% Biodiesel	%	*In-House	<20.0	<b>0.0</b>	---	---
Calcium	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Magnesium	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Phosphorus	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Zinc	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---

## FUEL CONDITION

Sulfur value derived by ASTM D5453 method for ULSD validation.

ASTM Color	scalar	*ASTM D1500		<b>L5.5</b>	---	---
Visc @ 40°C	cSt	ASTM D445		<b>2.36</b>	---	---
Sulfur	ppm	ASTM D5185m		<b>16</b>	---	---
Sulfur (UVF)	ppm	ASTM D5453		<b>18</b>	---	---



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : DC0029142  
**Lab Number** : 06089191  
**Unique Number** : 10876636  
**Test Package** : DF-5 ( Additional Tests: API, Screen )

**Received** : 14 Feb 2024  
**Tested** : 19 Feb 2024  
**Diagnosed** : 19 Feb 2024 - Doug Bogart

**KELLY GENERATOR & EQUIPMENT INC**  
 1955 DALE LN  
 OWINGS, MD  
 US 20736

Contact: LESLIE SNURR  
 LSNURR@KGE.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (410)257-5225  
 F: (410)257-5227