

## Machine Id 833013 Component Natural Gas Engine Fluid PETRO CANADA DURON SHP 15W40 (32 QTS)

	/						
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		GFL0106847	GFL0084630	GFL0084592
	Sample Date		Client Info		12 Feb 2024	24 Nov 2023	13 Sep 2023
	Machine Age	hrs	Client Info		4853	4348	0
	Oil Age	hrs	Client Info		0	600	0
	Filter Age	hrs	Client Info		0	600	0
	Oil Changed		Client Info		N/A	Changed	Changed
	Filter Changed		Client Info		N/A	Changed	Changed
	Sample Status				NORMAL	NORMAL	NORMAL
WEAR	Iron	ppm	ASTM D5185m	>50	10	8	9
	Chromium	ppm	ASTM D5185m	>4	<1	<1	<1
All component wear rates are normal.	Nickel	ppm	ASTM D5185m	>2	0	<1	0
	Titanium	ppm	ASTM D5185m		0	<1	0
	Silver	ppm	ASTM D5185m	>3	0	0	0
	Aluminum	ppm	ASTM D5185m	>9	1	2	0
	Lead	ppm	ASTM D5185m	>30	<1	<1	0
	Copper	ppm	ASTM D5185m	>35	1	1	0
	Tin	ppm	ASTM D5185m	>4	<1	<1	<1
	Vanadium	ppm	ASTM D5185m		0	0	0
	White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
CONTAMINATION	Silicon	ppm	ASTM D5185m	>+100	4	5	4
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m	>20	0	2	0
	Water		WC Method	>0.1	NEG	NEG	NEG
	Soot %	%	*ASTM D7844		0	0	0.1
	Nitration	Abs/cm	*ASTM D7624	>20	10.5	11.2	9.6
	Sulfation	Abs/.1mm	*ASTM D7415	>30	20.1	21.4	20.2
	Silt	scalar	*Visual	NONE	NONE	NONE	NONE
	Debris	scalar	*Visual	NONE	NONE	NONE	NONE
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
	Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
	Odor	scalar	*Visual	NORML	NORML	NORML	NORML
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
FLUID CONDITION	Sodium	ppm	ASTM D5185m		7	3	6
The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m	0	10	7	18
	Barium	ppm	ASTM D5185m		0	0	0
	Molybdenum	ppm	ASTM D5185m		52	53	52
	Manganese	ppm	ASTM D5185m		<1	<1	<1
	Magnesium	ppm	ASTM D5185m		547	551	624
	Calcium	ppm	ASTM D5185m		1559	1626	1664
	Phosphorus	ppm	ASTM D5185m		733	646	710
	Zinc	ppm	ASTM D5185m		950	961	953
	Sulfur	ppm	ASTM D5185m		2496	2564	2866
	Ovidation	Abo/ 1mm	*ACTM D7414	- 0E	170	10.0	17.0

Oxidation

18.3

14.9

17.2

15.0

4.5 6.5

17.3


5.2

14.7

Abs/.1mm \*ASTM D7414 >25

Base Number (BN) mg KOH/g ASTM D2896 9.8

Visc @ 100°C cSt ASTM D445 15.4



\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Т:

F: