

WEAR ABNORMAL CONTAMINATION ABNORMAL FLUID CONDITION NORMAL

Limit/Abn Current

Historv1

History2

Machine Id SULZER P-2202A Component Pump Fluid {not provided} (1 GAL) RECOMMENDATION

No corrective action is recommended at this time. We recommend an early resample to monitor this condition.

Test

UOM

Method

The iron level is abnormal.

CONTAMINATION

Elemental level of silicon (Si) above normal indicating ingress of seal material.

	Sample Number		Client Info		TO60002327	
	Sample Date		Client Info		16 Feb 2024	
	Machine Age	mths	Client Info		3	
	Oil Age	mths	Client Info		0	
	Filter Age	mths	Client Info		0	
	Oil Changed		Client Info		N/A	
	Filter Changed		Client Info		N/A	
	Sample Status				ABNORMAL	
	PQ		ASTM D8184		81	
	Iron	ppm	ASTM D5185m	>75	A 204	
	Chromium	ppm	ASTM D5185m	>5	5	
	Nickel	ppm	ASTM D5185m		<1	
	Titanium	ppm	ASTM D5185m		<1	
	Silver	ppm	ASTM D5185m		<1	
	Aluminum	ppm	ASTM D5185m	>5	<1	
	Lead	ppm	ASTM D5185m	>10	1	
	Copper	ppm	ASTM D5185m	>15	4	
	Tin	ppm	ASTM D5185m		<1	
	Vanadium	ppm	ASTM D5185m		0	
	White Metal	scalar	*Visual	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	
	Silicon	ppm	ASTM D5185m	>20	A 29	
	Potassium	ppm	ASTM D5185m	>20	0	
	Water		WC Method	>.1	NEG	
	Silt	scalar	*Visual	NONE	NONE	
	Debris	scalar	*Visual	NONE	NONE	
	Sand/Dirt	scalar	*Visual	NONE	NONE	
	Appearance	scalar	*Visual	NORML	NORML	
	Odor	scalar	*Visual	NORML	NORML	
	Emulsified Water	scalar	*Visual	>.1	NEG	
	Sodium	maa	ASTM D5185m		0	
	Boron	ppm	ASTM D5185m		0	
	Barium	ppm	ASTM D5185m		5	
	Molybdenum	ppm	ASTM D5185m		4	
	Manganese	ppm	ASTM D5185m		2	
	Magnesium	ppm	ASTM D5185m		0	
	Calcium	ppm	ASTM D5185m		19	
	Phosphorus	ppm	ASTM D5185m		105	
	Zinc	ppm	ASTM D5185m		165	
	Sulfur	ppm	ASTM D5185m		1772	
	Visc @ 40°C	cSt	ASTM D445		43.1	
	Visc @ 100°C	cSt	ASTM D445		6.5	
	Viscosity Index (VI)	Scale	ASTM D2270		100	
		00010				

FLUID CONDITION

The condition of the oil is acceptable for the time in service.



JG INDUSTRIAL CONTRACTORS INC Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. Received 601 N SOUTH ST : TO60002327 : 22 Feb 2024 Lab Number : 06097999 PASADENA, TX Tested : 26 Feb 2024 Unique Number : 10896229 Diagnosed : 26 Feb 2024 - Jonathan Hester US 77503-2568 Test Package : IND 2 (Additional Tests: KV100, PQ, VI) Contact: Service Manager Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F:

Contact/Location: Service Manager - JGIPAS