

CORROSION CONTAMINANTS FUEL CONDITION **NORMAL NORMAL NORMAL**


Area [3186660]


3039557

Component Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.	Sample Number		Client Info		DC0034676	DC0019291	
	Sample Date		Client Info		21 Feb 2024	01 Feb 2022	
	Machine Age	hrs	Client Info		0	380	
	Sample Status				NORMAL	NORMAL	
CORROSION	Aluminum	ppm	ASTM D5185m	<0.1	0	0	
All metal levels are normal indicating no corrosion in the system.	Nickel	ppm	ASTM D5185m	<0.1	<1	0	
	Lead	ppm	ASTM D5185m	<0.1	0	0	
	Vanadium	ppm	ASTM D5185m	<0.1	0	0	
	Iron	ppm	ASTM D5185m	<0.1	0	0	
CONTAMINANTS	Silicon	ppm	ASTM D5185m	<1.0	0	0	
The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel.	Sodium	ppm	ASTM D5185m	<0.1	<1	0	
	Potassium	ppm	ASTM D5185m	<0.1	<1	0	
	Water	%	ASTM D6304	<0.05	0.002	0.003	
	ppm Water	ppm	ASTM D6304	<500	21	29.8	
	Particles >4μm		ASTM D7647	>2500		292	
	Particles >6μm		ASTM D7647	>640		86	
	Particles >14µm		ASTM D7647	>80		8	
	Particles >21µm		ASTM D7647	>20		2	
	Particles >38µm		ASTM D7647	>4		0	
	Particles >71μm		ASTM D7647	>3		0	
	Oil Cleanliness		ISO 4406 (c)	>18/16/13		15/14/10	
	% Gasoline	%	*In-House	<0.50	0.0	0.0	
	% Biodiesel	%	*In-House	<20.0	0.0	0.0	
	Calcium	ppm	ASTM D5185m		<1	0	
	Magnesium	ppm	ASTM D5185m		0	0	
	Phosphorus	ppm	ASTM D5185m		<1	1	
	Zinc	ppm	ASTM D5185m	<0.1	0	0	
FUEL CONDITION Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.	ASTM Color	scalar	*ASTM D1500		L4.5	L5.5	
	Visc @ 40°C	cSt	ASTM D445	3.0	2.27	2.48	
	Sulfur	ppm	ASTM D5185m	10	<1	2	
	Sulfur (UVF)	ppm	ASTM D5453		8	7	
	API Gravity		ASTM D7777	37.7	37.1	36.9	







Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : DC0034676 Lab Number : 06098060

Unique Number : 10896290

Received **Tested** Diagnosed

: 22 Feb 2024 : 27 Feb 2024

: 27 Feb 2024 - Doug Bogart **Test Package**: DF-5 (Additional Tests: API, Cetane, Fuel, Screen)

KELLY GENERATOR & EQUIPMENT INC 1955 DALE LN OWINGS, MD US 20736

Contact: LESLIE SNURR LSNURR@KGE.COM T: (410)257-5225

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (410)257-5227

Contact/Location: LESLIE SNURR - KELOWI