CORROSION
CONTAMINANTS
COOLANT CONDITION

NORMAL

ABNORMAL

NORMAL

Area

[3186660]

2137384

Component Coolant

HYBRID (HOAT) COOLANT (--- GAL)

COI			

We recommend drain/flush system, and refill with 50/50 antifreeze water mixture. We advise that you replenish the supplemental coolant additives (SCAs) and add per manufacturer`s recommendations.

Test	UOM	Method	Limit/Abn	Current	History1	/1 History2	
Sample Number		Client Info		DC0034215	DC0025603	DC0017051	
Sample Date		Client Info		21 Feb 2024	09 Feb 2023	01 Feb 2022	
Machine Age	hrs	Client Info		0	655	55	
Oil Age	hrs	Client Info		0	0	0	
Oil Changed		Client Info		N/A	N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
Total Dissolved Solids				181.0	306.0	282.5	
Coolant Appearance		*Visual	Clear	sediment	normal	normal	
Specific Gravity		*ASTM D1298		1.067	1.067		
рН	Scale 0-14	ASTM D1287		8.51	8.45	8.37	
Nitrites	ppm	AP-053:2009		1088	<u> </u>	<u>224</u>	
Reserve Alkalinity	Scale 0-20	*ASTM D1121					
Percentage Glycol	%	ASTM D3321		49.4	49.7	50	

-33

n/a

Red

-33

n/a

Yllow

n/a

Yllow

ASTM D3321

*Visual

Freezing Point


Carboxylate


Coolant Color

CONTAMINANTS

CORROSION

There is a high concentration of visible sediment in the coolant.









Laboratory Sample No.

Lab Number : 06098071 Unique Number : 10896301

: DC0034215

Received **Tested** Diagnosed

: 23 Feb 2024 Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

: 22 Feb 2024

: 29 Feb 2024 - Doug Bogart

1955 DALE LN OWINGS, MD US 20736 Contact: LESLIE SNURR LSNURR@KGE.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

T: (410)257-5225 F: (410)257-5227 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: KELOWI [WUSCAR] 06098071 (Generated: 02/29/2024 09:05:12) Rev: 1

Contact/Location: LESLIE SNURR - KELOWI