**WEAR** CONTAMINATION **FLUID CONDITION** 


**NORMAL NORMAL** NORMAL

**NOT GIVEN** 

## **INGERSOLL RAND KE6336U98285 - NALCO 3**

Component Compressor

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		UCH06098512		
Tresumple at the next service interval to monitor.	Sample Date		Client Info		15 Feb 2024		
	Machine Age	hrs	Client Info		583		
	Oil Age	hrs	Client Info		8000		
	Filter Age	hrs	Client Info		8000		
	Oil Changed		Client Info		Changed		
	Filter Changed		Client Info		Changed		
	Sample Status				NORMAL		
WEAR			AOTA DEADE				
WEAR All component wear rates are normal.	Iron	ppm	ASTM D5185m		0		
	Chromium	ppm	ASTM D5185m	>10	0		
	Nickel	ppm	ASTM D5185m		<1		
	Titanium	ppm	ASTM D5185m		0		
	Silver	ppm	ASTM D5185m	05	0		
	Aluminum	ppm	ASTM D5185m		<1		
	Lead	ppm	ASTM D5185m		0		
	Copper	ppm	ASTM D5185m		<1		
	Tin	ppm	ASTM D5185m	>15	<1		
	Vanadium	ppm	ASTM D5185m	NONE	0		
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
CONTAMINATION	Silicon	ppm	ASTM D5185m	>25	8		
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m	>20	<1		
	Water		WC Method	>0.1	NEG		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
	Odor	scalar	*Visual	NORML	NORML		
	<b>Emulsified Water</b>	scalar	*Visual	>0.1	NEG		
EL LUD CONDITION	0 - 45		AOTA D5405				
FLUID CONDITION	Sodium	ppm	ASTM D5185m		<1		
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m		0		
	Barium	ppm	ASTM D5185m		3		
	Molybdenum	ppm	ASTM D5185m		0		
	Manganese	ppm	ASTM D5185m		<1		
	Magnesium	ppm	ASTM D5185m		1		
	Calcium	ppm	ASTM D5185m		2		
	Phosphorus	ppm	ASTM D5185m		931		
	Zinc	ppm	ASTM D5185m		19		
	Sulfur	ppm ma KOU/a	ASTM D5185m		289		
	Acid Number (AN)	mg KOH/g	ASTM D8045		0.046		
Report Id: UCGRECLA [WUSCAR] 06098512 (Generated: 02/27/2024 09:07:00) Rev: 1	Visc @ 40°C	cSt	ASTM D445	. //	<b>47.9</b> on: ASHLEY		







Certificate L2367

Laboratory Sample No.

Lab Number : 06098512 Unique Number : 10896742 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCH06098512 Received : 23 Feb 2024 : 26 Feb 2024 **Tested** 

: 26 Feb 2024 - Don Baldridge Diagnosed

₹ 0.02

0.01

0.00

11974 E 530 RD CLAREMORE, OK US 74019

**GREEN COUNTY COMPRESSOR SERVICE** 

Contact: ASHLEY PIGUET ashley@gccs.us.com T: (918)906-6343

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

39 38

Feb15/24

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)