

Machine Id **301** Component **Compressor** Fluid **VILTER SF PAO 150 (--- QTS) RECOMMENDATION**

Resample at the next service interval to monitor.

W	EA	R

All component wear rates are normal.

CONTAMINATION


There is no indication of any contamination in the oil.


			_
FLU		$\mathbf{N}\mathbf{D}$	ONE
	\mathbf{U}		

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0858372		
Sample Date		Client Info		20 Feb 2024		
Machine Age	hrs	Client Info		2295		
Oil Age	hrs	Client Info		2295		
Filter Age	hrs	Client Info		2295		
Oil Changed		Client Info		Not Changd		
Filter Changed		Client Info		Not Changd		
Sample Status				NORMAL		
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>5	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		<1		
Aluminum	ppm	ASTM D5185m	>15	<1		
Lead	ppm	ASTM D5185m	>65	<1		
Copper	ppm	ASTM D5185m	>65	2		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		<1		
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Silicon	ppm	ASTM D5185m	>35	2		
Potassium	ppm	ASTM D5185m	>20	1		
Water		WC Method	>0.1	NEG		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	LIGHT		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Sodium	ppm	ASTM D5185m		14		
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		13		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		18		
Phosphorus	ppm	ASTM D5185m		2		
Zinc	ppm	ASTM D5185m		24		
Sulfur	ppm	ASTM D5185m		25		
Acid Number (AN)	mg KOH/g	ASTM D8045		0.081		
Visc @ 40°C	cSt	ASTM D445		144		

Contact/Location: PHIL PRIEBE - TERSUF





Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 **TERREVA RENEWABLES - SPSA** Sample No. 1 BOB FOELLER DR : WC0858372 Received : 23 Feb 2024 Lab Number : 06099282 Tested : 27 Feb 2024 SUFFOLK, VA Unique Number : 10897512 : 28 Feb 2024 - Jonathan Hester US 23434 Diagnosed Test Package : MOB 2 Contact: PHIL PRIEBE Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. ppriebe@terrevarenewables.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (815)671-3576 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F:

Ş

Đ8

ø

Contact/Location: PHIL PRIEBE - TERSUF