



# OIL ANALYSIS REPORT

WEAR	<b>NORMAL</b>
CONTAMINATION	<b>NORMAL</b>
FLUID CONDITION	<b>NORMAL</b>

Area  
**WQ**  
Machine Id  
**DEISTER 00125**  
Component  
**Final Drive**  
Fluid  
**GEAR OIL ISO 150 (7 GAL)**

## RECOMMENDATION

Resample at the next service interval to monitor.

## WEAR

All component wear rates are normal.











## CONTAMINATION

There is no indication of any contamination in the oil.

## FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>LP0000965</b>	WC0570603	WC0524335
Sample Date		Client Info		<b>25 Feb 2024</b>	17 Jan 2023	07 Feb 2022
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Filter Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed		Client Info		<b>N/A</b>	N/A	N/A
Filter Changed		Client Info		<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL
Iron	ppm	ASTM D5185m	>500	<b>68</b>	134	321
Chromium	ppm	ASTM D5185m	>10	<b>&lt;1</b>	<1	3
Nickel	ppm	ASTM D5185m	>10	<b>&lt;1</b>	0	<1
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	1	5
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>25	<b>5</b>	5	17
Lead	ppm	ASTM D5185m	>25	<b>7</b>	<1	3
Copper	ppm	ASTM D5185m	>50	<b>25</b>	3	33
Tin	ppm	ASTM D5185m	>10	<b>&lt;1</b>	<1	1
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
White Metal	scalar	*Visual	NONE	<b>NONE</b>	MODER	VLITE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silicon	ppm	ASTM D5185m	>75	<b>20</b>	17	64
Potassium	ppm	ASTM D5185m	>20	<b>3</b>	1	7
Water		WC Method	>0.2	<b>NEG</b>	NEG	NEG
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	LIGHT	VLITE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	<b>NEG</b>	NEG	NEG
Sodium	ppm	ASTM D5185m		<b>2</b>	2	4
Boron	ppm	ASTM D5185m	50	<b>1</b>	25	4
Barium	ppm	ASTM D5185m	15	<b>0</b>	0	8
Molybdenum	ppm	ASTM D5185m	15	<b>0</b>	<1	<1
Manganese	ppm	ASTM D5185m		<b>1</b>	2	2
Magnesium	ppm	ASTM D5185m	50	<b>3</b>	1	4
Calcium	ppm	ASTM D5185m	50	<b>8</b>	18	11
Phosphorus	ppm	ASTM D5185m	350	<b>193</b>	273	172
Zinc	ppm	ASTM D5185m	100	<b>7</b>	16	20
Sulfur	ppm	ASTM D5185m	12500	<b>5381</b>	7816	11913
Acid Number (AN)	mg KOH/g	ASTM D8045	0.85	<b>0.18</b>	0.62	0.30
Visc @ 40°C	cSt	ASTM D445	150	<b>141</b>	140	150



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : LP0000965  
**Lab Number** : 06100251  
**Unique Number** : 10898481  
**Test Package** : MOB 2  
**Received** : 26 Feb 2024  
**Tested** : 27 Feb 2024  
**Diagnosed** : 27 Feb 2024 - Wes Davis

**S.M. LORUSSO & SONS**  
 221 NORFOLK ST.  
 WALPOLE, MA  
 US 02081  
 Contact: PAUL BECKMAN  
 pbeckman@smlorusso.com  
 T: (508)668-2603  
 F: (508)660-0232

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)