



COOLANT REPORT

| | |
|-------------------|---------------|
| CORROSION | NORMAL |
| CONTAMINANTS | NORMAL |
| COOLANT CONDITION | NORMAL |

Area
5C07
Machine Id
UTILITY VS2DX TRAILER RTR8432 (S/N 1UYVS24898M418901)
Component
Coolant
Fluid
CONVENTIONAL COOLANT (--- GAL)

RECOMMENDATION

The fluid is suitable for further service.

| Test | UOM | Method | Limit/Abn | Current | History1 | History2 |
|---------------|-----|-------------|-----------|--------------------|-------------|----------|
| Sample Number | | Client Info | | ARI06100616 | ARI0003624 | --- |
| Sample Date | | Client Info | | 25 Feb 2024 | 07 Feb 2022 | --- |
| Machine Age | hrs | Client Info | | 17169 | 0 | --- |
| Oil Age | hrs | Client Info | | 0 | 0 | --- |
| Oil Changed | | Client Info | | N/A | N/A | --- |
| Sample Status | | | | NORMAL | NORMAL | --- |








CORROSION

| | | | | | | |
|------------------------|--|---------|-------|---------------|--------|-----|
| Total Dissolved Solids | | | | 323.0 | 341.0 | --- |
| Coolant Appearance | | *Visual | Clear | normal | normal | --- |

CONTAMINANTS

There is no indication of any contamination in the coolant.

| | | | | | | |
|--------------------|------------|-------------|--|---------------|-------|-----|
| Specific Gravity | | *ASTM D1298 | | 1.064 | 1.064 | --- |
| pH | Scale 0-14 | ASTM D1287 | | 8.11 | 7.56 | --- |
| Nitrites | ppm | AP-053:2009 | | 976 | 184 | --- |
| Reserve Alkalinity | Scale 0-20 | *ASTM D1121 | | --- | --- | --- |
| Percentage Glycol | % | ASTM D3321 | | 47.5 | 47.4 | --- |
| Freezing Point | °F | ASTM D3321 | | -28 | -28 | --- |
| Carboxylate | | | | n/a | n/a | --- |
| Coolant Color | | *Visual | | Yellow | Pink | --- |



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : ARI06100616 **Received** : 26 Feb 2024
Lab Number : 06100616 **Tested** : 27 Feb 2024
Unique Number : 10898846 **Diagnosed** : 28 Feb 2024 - Jonathan Hester
Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

INSITUFORM TECHNOLOGIES, INC
 17988 EDISON AVE.
 CHESTERFIELD, MO
 US 63005
 Contact: JOHN SLOAN
 ARICHTER@INSITUFORM.COM
 T: (314)280-7555
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)