WEAR CONTAMINATION FLUID CONDITION

NORMAL ABNORMAL NORMAL


{UNASSIGNED}

YORK York #6 (S/N SAHM-467620)

Centrifugal Compressor

RECOMMENDATION	Toot	LICA	Mother	Limit/Alas	O	Llioto::::4	Lliete
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
No corrective action is recommended at this time. Resample at the next service interval to monitor. (Customer Sample Comment: Annual test)	Sample Number		Client Info		WC0758318	WC0426156	
	Sample Date	hvo	Client Info		06 Feb 2024 10468	14 Feb 2023	
	Machine Age Oil Age	hrs	Client Info		10468	6739 0	
	Filter Age	hrs hrs	Client Info		0	0	
	Oil Changed	1113	Client Info		N/A	Not Changd	
	Filter Changed		Client Info		N/A	Not Changd	
	Sample Status		Onone into		ABNORMAL	NORMAL	
WEAR	Iron	ppm	ASTM D5185m	>50	0	2	
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>10	<1	0	
	Nickel	ppm	ASTM D5185m		0	0	
	Titanium	ppm	ASTM D5185m		0	0	
	Silver	ppm	ASTM D5185m		0	0	
	Aluminum	ppm	ASTM D5185m	>25	0	0	
	Lead	ppm	ASTM D5185m		0	0	
	Copper	ppm	ASTM D5185m		0	0	
	Tin	ppm	ASTM D5185m	>15	0	0	
	Vanadium	ppm	ASTM D5185m		0	0	
	White Metal	scalar	*Visual	NONE	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
CONTAMINATION	Silicon	ppm	ASTM D5185m	>25	▲ 36	6	
Elemental level of silicon (Si) above normal indicating ingress of seal material.	Potassium	ppm	ASTM D5185m	>20	0	1	
	Water	%	ASTM D6304	>0.03	0.006	0.014	
	ppm Water	ppm	ASTM D6304	>300	63	142.7	
	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	NONE	NONE	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
	Appearance	scalar	*Visual	NORML	NORML	NORML	
	Odor	scalar	*Visual	NORML	NORML	NORML	
	Emulsified Water	scalar	*Visual	>0.03	NEG	NEG	
	0 11	ppm	ASTM D5185m		0	0	
FLUID CONDITION	Sodium						
FLUID CONDITION The AN level is generable for this fluid. The condition of the cill is	Boron	ppm	ASTM D5185m	0	0	0	
FLUID CONDITION The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.			ASTM D5185m ASTM D5185m		0 1	0 4	
The AN level is acceptable for this fluid. The condition of the oil is	Boron	ppm		0			
The AN level is acceptable for this fluid. The condition of the oil is	Boron Barium	ppm ppm	ASTM D5185m	0	1	4	
The AN level is acceptable for this fluid. The condition of the oil is	Boron Barium Molybdenum	ppm ppm	ASTM D5185m ASTM D5185m	0 0 0	1 0	4 0	
The AN level is acceptable for this fluid. The condition of the oil is	Boron Barium Molybdenum Manganese	ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m	0 0 0	1 0 <1	4 0 0	
The AN level is acceptable for this fluid. The condition of the oil is	Boron Barium Molybdenum Manganese Magnesium	ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 0 0	1 0 <1 <1	4 0 0 0	
The AN level is acceptable for this fluid. The condition of the oil is	Boron Barium Molybdenum Manganese Magnesium Calcium	ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 0 0 0 5	1 0 <1 <1 1	4 0 0 0 0	
The AN level is acceptable for this fluid. The condition of the oil is	Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus	ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 0 0 0 5	1 0 <1 <1 1	4 0 0 0 0 0	
The AN level is acceptable for this fluid. The condition of the oil is	Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	0 0 0 0 0 5 0	1 0 <1 <1 1 <1	4 0 0 0 0 0 10	

31.2







Certificate L2367

Laboratory Sample No.

: WC0758318 Lab Number : 06101682 **Unique Number** : 10899912 Test Package : PLANT

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 27 Feb 2024 **Tested**

: 29 Feb 2024 : 29 Feb 2024 - Jonathan Hester Diagnosed

DAIKIN APPLIED - AUBURN HILLS 3955 PINNACLE COURT SUITE 300

AUBURN HILLS, MI US 48326

Contact: MICHELLE MANN

michelle.mann@daikinapplied.com T: (248)364-4532

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (248)364-4530