

CORROSION CONTAMINANTS COOLANT CONDITION

NORMAL NORMAL ABNORMAL

Area **622** [983532] **622 CHILLER**

Component Coolant

HYBRID (HOAT) COOLANT (GAL)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
We recommend drain system, and refill with 50/50 antifreeze water mixture. We advise that you replenish the supplemental coolant additives (SCAs) and add per manufacturer`s specifications.	Sample Number		Client Info		WC0897112	WC0786938	WC0670563
	Sample Date		Client Info		22 Feb 2024	06 Mar 2023	28 Feb 2022
	Machine Age	hrs	Client Info		0	0	50832
	Oil Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		N/A	N/A	N/A
	Sample Status				ABNORMAL	NORMAL	NORMAL
ORROSION Total Dissolved Solids					191.0	570.0	277.5
	Coolant Appearance		*Visual	Clear	normal	normal	normal
CONTAMINANTS	Specific Gravity		*ASTM D1298		1.035	1.086	
There is no indication of any contamination in the coolant.	рН	Scale 0-14	ASTM D1287		8.65	9.51	9.04
	Nitrites	ppm	AP-053:2009		300	676	184
	Reserve Alkalinity	Scale 0-20	*ASTM D1121				
	Percentage Glycol	%	ASTM D3321		26.5	66.3	35
	Freezing Point	°F	ASTM D3321		9	-65	-5
	Carboxylate				n/a	n/a	n/a


Coolant Color


*Visual

Clear

Yllow

Clear







Report Id: BALKEA [WUSCAR] 06103450 (Generated: 03/04/2024 20:26:32) Rev: 1

Laboratory Sample No.

: WC0897112 Lab Number : 06103450 Unique Number: 10901680

Received **Tested** Diagnosed

: 04 Mar 2024 : 04 Mar 2024 - Jonathan Hester

: 28 Feb 2024

Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

BALDWIN FILTERS INC 4400 HIGHWAY 30 EAST KEARNEY, NE

US 68847-0724 Contact: JAY FAHRENBRUCH

jay.fahrenbruch@parker.com

T: F: (800)828-4453

Contact/Location: JAY FAHRENBRUCH - BALKEA