



COOLANT REPORT

CORROSION	NORMAL
CONTAMINANTS	NORMAL
COOLANT CONDITION	NORMAL

Area
[PMIAS3286597]
 Machine Id
DQFAD A110182208 (S/N A110187208)
 Component
Coolant
 Fluid
CONVENTIONAL COOLANT (35 GAL)

RECOMMENDATION

The fluid is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		DC0033816	DC0019155	DC0027700
Sample Date		Client Info		15 Feb 2024	02 Aug 2023	21 Feb 2023
Machine Age	hrs	Client Info		309	302	299
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	N/A	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL








CORROSION

Total Dissolved Solids				579.5	649.0	599.0
Coolant Appearance		*Visual	Clear	normal	normal	normal

CONTAMINANTS

There is no indication of any contamination in the coolant.

Specific Gravity		*ASTM D1298		1.067	1.067	1.067
pH	Scale 0-14	ASTM D1287		9.01	8.04	8.99
Nitrites	ppm	AP-053:2009		2440	2516	2440
Reserve Alkalinity	Scale 0-20	*ASTM D1121		---	---	---
Percentage Glycol	%	ASTM D3321		49.7	49.9	49.2
Freezing Point	°F	ASTM D3321		-33	-33	-33
Carboxylate				n/a	n/a	n/a
Coolant Color		*Visual		Green	Green	Green



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0033816
Lab Number : 06103454
Unique Number : 10901684
Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

KELLY GENERATOR & EQUIPMENT INC
 1955 DALE LN
 OWINGS, MD
 US 20736
 Contact: LESLIE SNURR
 LSNURR@KGE.COM
 T: (410)257-5225
 F: (410)257-5227

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)