WEAR CONTAMINATION **FLUID CONDITION**


NORMAL NORMAL NORMAL


(P633828)


3758C


Component Natural Gas Engine


RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number	OOW	Client Info	LITTIO/ NOT	GFL0101792	GFL0101743	
	Sample Date		Client Info		13 Mar 2024	23 Feb 2024	14 Jun 202
	Machine Age	hrs	Client Info		15720	15100	14378
	Oil Age	hrs	Client Info		600	600	600
	Filter Age	hrs	Client Info		600	600	600
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				NORMAL	NORMAL	NORMAI
A/CAD							
WEAR	Iron	ppm	ASTM D5185m		27	20	18
All component wear rates are normal.	Chromium	ppm	ASTM D5185m		5	2	3
	Nickel	ppm	ASTM D5185m	>2	1	0	1
	Titanium	ppm	ASTM D5185m	_	<1	0	<1
	Silver	ppm	ASTM D5185m		0	0	0
	Aluminum	ppm	ASTM D5185m		6	3	4
	Lead	ppm	ASTM D5185m		10	8	14
	Copper	ppm	ASTM D5185m		1	<1	2
	Tin	ppm	ASTM D5185m	>4	1	0	2
	Vanadium	ppm	ASTM D5185m	NONE	0	0	<1
	White Metal	scalar	*Visual	NONE	NONE	NONE	NON
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
CONTAMINATION	Silicon	ppm	ASTM D5185m	>+100	11	8	8
	Potassium	ppm	ASTM D5185m	>20	6	5	3
There is no indication of any contamination in the oil.	Water		WC Method	>0.1	NEG	NEG	NEG
	Soot %	%	*ASTM D7844		0	0	0.1
	Nitration	Abs/cm	*ASTM D7624	>20	12.6	12.5	11.8
	Sulfation	Abs/.1mm	*ASTM D7415	>30	27.5	26.9	25.8
	Silt	scalar	*Visual	NONE	NONE	NONE	NON
	Debris	scalar	*Visual	NONE	LIGHT	NONE	NON
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NON
	Appearance	scalar	*Visual	NORML	NORML	NORML	NORM
	Odor	scalar	*Visual	NORML	NORML	NORML	NORN
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
FLUID CONDITION	Sodium	ppm	ASTM D5185m		11	8	9
The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m	50	11	8	10
	Barium	ppm	ASTM D5185m		0	8	0
	Molybdenum	ppm	ASTM D5185m		61	59	56
	Manganese	ppm	ASTM D5185m		<1	0	2
	Magnesium	ppm	ASTM D5185m		646	589	718
	Calcium	ppm		1510	1843	1635	1745
	Phosphorus	ppm	ASTM D5185m		872	826	821
	Zinc	ppm		870	1113	992	1107
	Sulfur	ppm	ASTM D5185m		2651	2552	3118
	Oxidation	Ahs/ 1mm	*ASTM1)/414	>25	23.2	23.2	// 4
	Oxidation Base Number (BN)	Abs/.1mm mg KOH/g	*ASTM D7414 ASTM D2896		23.2 3.6	23.2 3.1	22.4
















Certificate L2367

Report Id: GFL030 [WUSCAR] 06121939 (Generated: 03/21/2024 11:26:53) Rev: 1

Laboratory Sample No.

: GFL0101792 Lab Number : 06121939 Unique Number : 10936090 Test Package : FLEET

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 19 Mar 2024 **Tested** : 19 Mar 2024

Diagnosed : 21 Mar 2024 - Jonathan Hester

GFL Environmental - 030 - Conway Myrtle Beach

3010 HWY 378 Conway, SC US 29527

Contact: ARCILIO RUEZ

aruiz@gflenv.com T:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: