## CORROSION CONTAMINANTS COOLANT CONDITION

NORMAL NORMAL NORMAL


[PMIAS3286416]

GENERAC 11567990800 2104927

Component Coolant

HYBRID (HOAT) COOLANT (--- GAL)

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service.	Sample Number		Client Info		DC0034014		
	Sample Date		Client Info		22 Feb 2024		
	Machine Age	hrs	Client Info		210		
	Oil Age	hrs	Client Info		0		
	Oil Changed		Client Info		Not Changd		
	Sample Status				NORMAL		
CORROSION	T. ID: 1 10 11						
CONNOSION	Total Dissolved Solids				547.0		
	Coolant Appearance		*Visual	Clear	normal		
CONTAMINANTS	Boiling Point	°C	WC Method		225		
There is no indication of any contamination in the coolant.	Specific Gravity		*ASTM D1298		1.068		
	рН	Scale 0-14	ASTM D1287		8.19		
	Nitrites	ppm	AP-053:2009		1088		
	Reserve Alkalinity	Scale 0-20	*ASTM D1121				
	Percentage Glycol	%	ASTM D3321		50.7		
	Freezing Point	°F	ASTM D3321		-35		
	Carboxylate				n/a		
	Coolant Color		*Visual		Yllow		







Laboratory Sample No.

Lab Number : 06122889 Unique Number : 10937040

: DC0034014

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 19 Mar 2024 **Tested** Diagnosed

: 21 Mar 2024 : 22 Mar 2024 - Jonathan Hester Test Package : COOL- ( Additional Tests: API, BoilingPoint, COOL, GlycolType )

2400

2000 1800

> **KELLY GENERATOR & EQUIPMENT INC** 1955 DALE LN OWINGS, MD US 20736

Contact: LESLIE SNURR Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. LSNURR@KGE.COM \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (410)257-5225

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (410)257-5227 Contact/Location: LESLIE SNURR - KELOWI