CORROSION CONTAMINANTS COOLANT CONDITION

NORMAL NORMAL NORMAL


[PMIAS3286198]


GENERAC 1156799010 2104933B

Component Coolant

HYBRID (HOAT) COOLANT (--- GAL)

in Bill (noar) coolain (carl)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service.	Sample Number		Client Info		DC0033102	DC0022593	DC0019170
	Sample Date		Client Info		22 Feb 2024	08 Mar 2023	13 Jan 2022
	Machine Age	hrs	Client Info		0	185	177
	Oil Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		N/A	Not Changd	N/A
	Sample Status				NORMAL	NORMAL	NORMAL
CORROSION	Total Dissolved Solids				596.5	535.0	594.0
	Coolant Appearance		*Visual	Clear	normal	normal	normal
CONTAMINANTS	Boiling Point	°C	WC Method		226		
There is no indication of any contamination in the coolant.	Specific Gravity		*ASTM D1298		1.069	1.069	
	рН	Scale 0-14	ASTM D1287		8.19	8.25	8.37
	Nitrites	ppm	AP-053:2009		1164	1012	1200
	Reserve Alkalinity	Scale 0-20	*ASTM D1121				
	Percentage Glycol	%	ASTM D3321		51.3	51.2	51
	Freezing Point	°F	ASTM D3321		-38	-38	-41
	Carboxylate				n/a	n/a	n/a
	Coolant Color		*Visual		Yllow	Yllow	Yllow









Certificate L2367

Laboratory Sample No.

: DC0033102 Lab Number : 06122890 Unique Number : 10937041

Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

Received : 19 Mar 2024 **Tested** : 22 Mar 2024 Diagnosed

: 22 Mar 2024 - Jonathan Hester

KELLY GENERATOR & EQUIPMENT INC 1955 DALE LN OWINGS, MD US 20736

Contact: LESLIE SNURR LSNURR@KGE.COM T: (410)257-5225

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

F: (410)257-5227 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Contact/Location: LESLIE SNURR - KELOWI