



OIL ANALYSIS REPORT

| | |
|-----------------|--------|
| WEAR | NORMAL |
| CONTAMINATION | NORMAL |
| FLUID CONDITION | NORMAL |

Area
SAM HORELICK
 Machine Id
B274V01857P
 Component
Propane Engine
 Fluid
{not provided} (--- GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

| Test | UOM | Method | Limit/Abn | Current | History1 | History2 |
|----------------|-----|-------------|-----------|-------------|----------|----------|
| Sample Number | | Client Info | | WC0908722 | --- | --- |
| Sample Date | | Client Info | | 14 Mar 2024 | --- | --- |
| Machine Age | hrs | Client Info | | 3858 | --- | --- |
| Oil Age | hrs | Client Info | | 1 | --- | --- |
| Filter Age | hrs | Client Info | | 1 | --- | --- |
| Oil Changed | | Client Info | | Changed | --- | --- |
| Filter Changed | | Client Info | | Changed | --- | --- |
| Sample Status | | | | NORMAL | --- | --- |

WEAR

All component wear rates are normal.

| | | | | | | |
|--------------|--------|-------------|------|------|-----|-----|
| Iron | ppm | ASTM D5185m | >100 | 3 | --- | --- |
| Chromium | ppm | ASTM D5185m | >25 | 0 | --- | --- |
| Nickel | ppm | ASTM D5185m | >5 | 0 | --- | --- |
| Titanium | ppm | ASTM D5185m | | 0 | --- | --- |
| Silver | ppm | ASTM D5185m | >5 | 0 | --- | --- |
| Aluminum | ppm | ASTM D5185m | >20 | 2 | --- | --- |
| Lead | ppm | ASTM D5185m | >25 | 0 | --- | --- |
| Copper | ppm | ASTM D5185m | >35 | 0 | --- | --- |
| Tin | ppm | ASTM D5185m | >8 | 0 | --- | --- |
| Vanadium | ppm | ASTM D5185m | | 0 | --- | --- |
| White Metal | scalar | *Visual | NONE | NONE | --- | --- |
| Yellow Metal | scalar | *Visual | NONE | NONE | --- | --- |

CONTAMINATION







There is no indication of any contamination in the oil.

| | | | | | | |
|------------------|----------|-------------|-------|-------|-----|-----|
| Silicon | ppm | ASTM D5185m | >50 | 12 | --- | --- |
| Potassium | ppm | ASTM D5185m | >20 | <1 | --- | --- |
| Water | | WC Method | >0.1 | NEG | --- | --- |
| Soot % | % | *ASTM D7844 | | 0 | --- | --- |
| Nitration | Abs/cm | *ASTM D7624 | >20 | 4.1 | --- | --- |
| Sulfation | Abs/.1mm | *ASTM D7415 | >30 | 13.1 | --- | --- |
| Silt | scalar | *Visual | NONE | NONE | --- | --- |
| Debris | scalar | *Visual | NONE | NONE | --- | --- |
| Sand/Dirt | scalar | *Visual | NONE | NONE | --- | --- |
| Appearance | scalar | *Visual | NORML | NORML | --- | --- |
| Odor | scalar | *Visual | NORML | NORML | --- | --- |
| Emulsified Water | scalar | *Visual | >0.1 | NEG | --- | --- |

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

| | | | | | | |
|------------------|----------|-------------|-----|------|-----|-----|
| Sodium | ppm | ASTM D5185m | | 0 | --- | --- |
| Boron | ppm | ASTM D5185m | | 92 | --- | --- |
| Barium | ppm | ASTM D5185m | | <1 | --- | --- |
| Molybdenum | ppm | ASTM D5185m | | 222 | --- | --- |
| Manganese | ppm | ASTM D5185m | | 0 | --- | --- |
| Magnesium | ppm | ASTM D5185m | | 479 | --- | --- |
| Calcium | ppm | ASTM D5185m | | 1326 | --- | --- |
| Phosphorus | ppm | ASTM D5185m | | 676 | --- | --- |
| Zinc | ppm | ASTM D5185m | | 882 | --- | --- |
| Sulfur | ppm | ASTM D5185m | | 3453 | --- | --- |
| Oxidation | Abs/.1mm | *ASTM D7414 | >25 | 6.6 | --- | --- |
| Base Number (BN) | mg KOH/g | ASTM D2896 | | 6.3 | --- | --- |
| Visc @ 100°C | cSt | ASTM D445 | | 12.8 | --- | --- |



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0908722

Lab Number : 06123384

Unique Number : 10937535

Test Package : CONST

Received : 20 Mar 2024

Tested : 21 Mar 2024

Diagnosed : 22 Mar 2024 - Don Baldrige

FORKLIFT SELECT

12875 E 42ND AVE, SUITE 50

DENVER, CO

US 80239

Contact: BYRON CHAPUIS

BYRON@FORKLIFTSELECT.COM

T:

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)