

Machine Id
M7 (S/N 1457487)
Component
Biogas Engine
Fluid
PETRO CANADA SENTRON LD 8000 (--- GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PCA0120728	PCA0106206	PCA0106211
Sample Date		Client Info		14 Mar 2024	18 Feb 2024	28 Jan 2024
Machine Age	hrs	Client Info		10591	10096	9590
Oil Age	hrs	Client Info		7582	7087	6591
Filter Age	hrs	Client Info		7582	7087	0
Oil Changed		Client Info		N/A	N/A	N/A
Filter Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL

WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>45	17	17	17
Chromium	ppm	ASTM D5185m	>2	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		0	<1	<1
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	2	2
Lead	ppm	ASTM D5185m	>5	3	3	3
Copper	ppm	ASTM D5185m	>14	<1	<1	<1
Tin	ppm	ASTM D5185m	>13	2	2	2
Vanadium	ppm	ASTM D5185m		0	0	0
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION













Fuel content negligible. There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>200	2	2	3
Potassium	ppm	ASTM D5185m	>20	0	3	3
Fuel	%	ASTM D3524	>4.0	0.2	0.3	0.2
Water		WC Method	>0.1	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	*ASTM D7844		0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	7.5	7.7	7.6
Sulfation	Abs/.1mm	*ASTM D7415	>30	22.6	22.7	22.6
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		11	10	11
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	<1	<1
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		9	11	11
Calcium	ppm	ASTM D5185m	1351	1897	1808	1891
Phosphorus	ppm	ASTM D5185m	302	344	307	317
Zinc	ppm	ASTM D5185m	358	438	454	462
Sulfur	ppm	ASTM D5185m	2758	3633	3264	3322
Oxidation	Abs/.1mm	*ASTM D7414	>25	18.1	18.4	18.1
Acid Number (AN)	mg KOH/g	ASTM D8045	0.86	2.18	2.15	2.06
Base Number (BN)	mg KOH/g	ASTM D2896	4.64	3.28	3.37	3.47
Visc @ 100°C	cSt	ASTM D445	13.3	14.2	14.1	14.0



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0120728
Lab Number : 06124366
Unique Number : 10938517
Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel)

Received : 20 Mar 2024
Tested : 23 Mar 2024
Diagnosed : 23 Mar 2024 - Don Baldrige

AMERICAN PETROLEUM
 CARR 865 KM 0.2 CAMPANILA
 TOA BAJA, PR
 US 00949
 Contact: NEFTALI ORTIZ
 nortiz@americanpetroleumpr.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (787)794-1985

F: