CORROSION CONTAMINANTS COOLANT CONDITION **NORMAL NORMAL NORMAL**


2H28


PETERBILT 348 RTK9845 REEFER (S/N 2NP3XJ0XXHM443145)

Component Coolant

EXTENDED LIFE COOLANT (--- GAL)

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service.	Sample Number		Client Info		ARI06125321	ARI04707938	ARI04625225
	Sample Date		Client Info		21 Mar 2024	01 May 2019	04 Jan 2019
	Machine Age	hrs	Client Info		11603	3217	2990
	Oil Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		N/A	N/A	N/A
	Sample Status				NORMAL	NORMAL	NORMAL
CORROSION	Total Dissolved Solids				217.5	399.0	419.5
	Coolant Appearance		*Visual	Clear	normal	normal	normal
CONTAMINANTS	Boiling Point	°C	WC Method		226		
There is no indication of any contamination in the coolant.	Specific Gravity		*ASTM D1298		1.070		
	рН	Scale 0-14	ASTM D1287		8.30	7.54	7.48
	Nitrites	ppm	AP-053:2009		712	712	560
	Reserve Alkalinity	Scale 0-20	*ASTM D1121				
	Percentage Glycol	%	ASTM D3321		52.4	56	55
	Freezing Point	°F	ASTM D3321		-40	-54	-52
	Carboxylate				n/a	n/a	n/a
	Coolant Color		*Visual		Red	Orange	Pink







Certificate L2367

Laboratory Sample No.

Lab Number : 06125321 Unique Number : 10939472

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : ARI06125321 Received : 21 Mar 2024 **Tested** : 26 Mar 2024

Diagnosed

: 26 Mar 2024 - Jonathan Hester Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

17988 EDISON AVE. CHESTERFIELD, MO US 63005

INSITUFORM TECHNOLOGIES, INC

Contact: JOHN SLOAN ARICHTER@INSITUFORM.COM T: (314)280-7555

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: