



# OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	SEVERE
FLUID CONDITION	NORMAL

Area  
**RIG 244**  
Machine Id  
**R244-MP-03**  
Component  
**Gearbox**  
Fluid  
**{not provided} (--- GAL)**

## RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. Please specify the component make and model with your next sample. Please specify the brand, type, and viscosity of the oil on your next sample.

## WEAR

All component wear rates are normal.










## CONTAMINATION

There is a high amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

## FLUID CONDITION

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>KL0014299</b>	KL0011757	KL0013739
Sample Date		Client Info		<b>03 Apr 2024</b>	11 Mar 2024	05 Mar 2024
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Filter Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed		Client Info		<b>N/A</b>	N/A	N/A
Filter Changed		Client Info		<b>N/A</b>	N/A	N/A
Sample Status				<b>SEVERE</b>	NORMAL	ABNORMAL
Iron	ppm	ASTM D5185m	>200	<b>11</b>	61	119
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185m	>10	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m		<b>0</b>	<1	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>25	<b>0</b>	2	3
Lead	ppm	ASTM D5185m	>50	<b>0</b>	<1	0
Copper	ppm	ASTM D5185m	>200	<b>12</b>	14	9
Tin	ppm	ASTM D5185m	>10	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silicon	ppm	ASTM D5185m	>50	<b>8</b>	16	18
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	5	5
Water		WC Method	>0.2	<b>NEG</b>	NEG	NEG
Particles >4µm		ASTM D7647	>20000	<b>▲ 134925</b>	---	---
Particles >6µm		ASTM D7647	>5000	<b>▲ 40294</b>	---	---
Particles >14µm		ASTM D7647	>640	<b>610</b>	---	---
Particles >21µm		ASTM D7647	>160	<b>106</b>	---	---
Particles >38µm		ASTM D7647	>40	<b>2</b>	---	---
Particles >71µm		ASTM D7647	>10	<b>0</b>	---	---
Oil Cleanliness		ISO 4406 (c)	>21/19/16	<b>▲ 24/23/16</b>	---	---
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	● MILKY
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	<b>NEG</b>	NEG	▲ 0.2%
Sodium	ppm	ASTM D5185m		<b>2</b>	20	54
Boron	ppm	ASTM D5185m		<b>0</b>	<1	7
Barium	ppm	ASTM D5185m		<b>2</b>	8	4
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	0
Manganese	ppm	ASTM D5185m		<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>1</b>	3	0
Calcium	ppm	ASTM D5185m		<b>7</b>	24	38
Phosphorus	ppm	ASTM D5185m		<b>118</b>	148	124
Zinc	ppm	ASTM D5185m		<b>0</b>	6	21
Sulfur	ppm	ASTM D5185m		<b>10964</b>	12385	10208
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.28</b>	---	0.37
Visc @ 40°C	cSt	ASTM D445		<b>315</b>	316	318



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KL0014299 **Received** : 11 Apr 2024  
**Lab Number** : 06145840 **Tested** : 12 Apr 2024  
**Unique Number** : 10975918 **Diagnosed** : 12 Apr 2024 - Wes Davis  
**Test Package** : MOB 2 ( Additional Tests: PrtCount )

**PATTERSON - UTI DRILLING**  
 9915 WEST INDUSTRIAL  
 MIDLAND, TX  
 US 79706  
 Contact: RICKY MATA  
 ricky.mata@patenergy.com  
 T: (832)219-4559  
 F: (432)561-9388

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)