



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	ABNORMAL
FLUID CONDITION	NORMAL

Machine Id  
**OAKWOOD VILLAGE EAST GRASSLANDS C-1B CIRC 1 (S/N U18C00507)**

Component  
**Refrigeration Compressor**

Fluid  
**TRANE 0048 (--- GAL)**

**RECOMMENDATION**

No corrective action is recommended at this time. We recommend an early resample to monitor this condition.

**WEAR**

All component wear rates are normal.

**CONTAMINATION**

There is a light concentration of water present in the oil.

**FLUID CONDITION**









The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>WC0730394</b>	WC0730372	WC0340235
Sample Date		Client Info		<b>10 Apr 2024</b>	17 Aug 2022	12 Aug 2021
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Filter Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed		Client Info		<b>N/A</b>	N/A	N/A
Filter Changed		Client Info		<b>N/A</b>	N/A	N/A
Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

Iron	ppm	ASTM D5185m	>8	<b>&lt;1</b>	<1	3
Chromium	ppm	ASTM D5185m	>2	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m		<b>0</b>	0	0
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m	>2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>3	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m	>2	<b>0</b>	0	1
Copper	ppm	ASTM D5185m	>8	<b>0</b>	0	1
Tin	ppm	ASTM D5185m	>4	<b>0</b>	<1	1
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE

Silicon	ppm	ASTM D5185m	>15	<b>3</b>	3	6
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	0	0
Water	%	ASTM D6304	>0.01	<b>▲ 0.055</b>	▲ 0.087	▲ 0.126
ppm Water	ppm	ASTM D6304	>100	<b>▲ 560</b>	▲ 879.9	▲ 1265.4
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	<b>NEG</b>	NEG	NEG

Sodium	ppm	ASTM D5185m		<b>0</b>	0	0
Boron	ppm	ASTM D5185m	1	<b>2</b>	1	8
Barium	ppm	ASTM D5185m	0	<b>0</b>	<1	0
Molybdenum	ppm	ASTM D5185m	0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	0	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m	0	<b>0</b>	0	0
Calcium	ppm	ASTM D5185m	0	<b>0</b>	0	0
Phosphorus	ppm	ASTM D5185m	5	<b>0</b>	2	4
Zinc	ppm	ASTM D5185m	0	<b>0</b>	0	0
Sulfur	ppm	ASTM D5185m	10	<b>0</b>	10	31
Acid Number (AN)	mg KOH/g	ASTM D974	0.09	<b>0.112</b>	0.076	0.062
Visc @ 40°C	cSt	ASTM D445	68	<b>56.2</b>	55.0	64.2



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0730394 **Received** : 11 Apr 2024  
**Lab Number** : 06145937 **Tested** : 12 Apr 2024  
**Unique Number** : 10976015 **Diagnosed** : 12 Apr 2024 - Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: PrtCount, PrtCountNAS )

**NORTH AMERICAN MECHANICAL**  
 4401 STATE RD 19  
 WINDSOR, WI  
 US 53598  
 Contact: STACEY QUAM  
 squam@naminc.com  
 T: (608)240-8906  
 F: (608)240-8965

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)