



# OIL ANALYSIS REPORT

|                 |               |
|-----------------|---------------|
| WEAR            | <b>NORMAL</b> |
| CONTAMINATION   | <b>NORMAL</b> |
| FLUID CONDITION | <b>NORMAL</b> |



Machine Id  
**ENG 7**  
Component  
**Right Biogas Engine**  
Fluid  
**AMERICAN REFINING GROUP LOW ASH 40 (110 GAL)**

## RECOMMENDATION

Resample at the next service interval to monitor.

| Test           | UOM | Method      | Limit/Abn | Current            | History1    | History2    |
|----------------|-----|-------------|-----------|--------------------|-------------|-------------|
| Sample Number  |     | Client Info |           | <b>WC0909645</b>   | WC0909653   | WC0909638   |
| Sample Date    |     | Client Info |           | <b>08 Apr 2024</b> | 01 Apr 2024 | 25 Mar 2024 |
| Machine Age    | hrs | Client Info |           | <b>73119</b>       | 72952       | 72786       |
| Oil Age        | hrs | Client Info |           | <b>906</b>         | 739         | 573         |
| Filter Age     | hrs | Client Info |           | <b>906</b>         | 739         | 573         |
| Oil Changed    |     | Client Info |           | <b>N/A</b>         | N/A         | N/A         |
| Filter Changed |     | Client Info |           | <b>N/A</b>         | N/A         | N/A         |
| Sample Status  |     |             |           | <b>NORMAL</b>      | NORMAL      | NORMAL      |

## WEAR

All component wear rates are normal.

|              |        |             |      |              |      |      |
|--------------|--------|-------------|------|--------------|------|------|
| Iron         | ppm    | ASTM D5185m | >45  | <b>10</b>    | 8    | 5    |
| Chromium     | ppm    | ASTM D5185m | >2   | <b>&lt;1</b> | <1   | 0    |
| Nickel       | ppm    | ASTM D5185m | >2   | <b>1</b>     | <1   | <1   |
| Titanium     | ppm    | ASTM D5185m |      | <b>&lt;1</b> | <1   | 0    |
| Silver       | ppm    | ASTM D5185m | >5   | <b>&lt;1</b> | 0    | 0    |
| Aluminum     | ppm    | ASTM D5185m | >10  | <b>3</b>     | 3    | 3    |
| Lead         | ppm    | ASTM D5185m | >5   | <b>2</b>     | 1    | 2    |
| Copper       | ppm    | ASTM D5185m | >14  | <b>1</b>     | <1   | <1   |
| Tin          | ppm    | ASTM D5185m | >13  | <b>5</b>     | 4    | 3    |
| Vanadium     | ppm    | ASTM D5185m |      | <b>&lt;1</b> | <1   | 0    |
| White Metal  | scalar | *Visual     | NONE | <b>NONE</b>  | NONE | NONE |
| Yellow Metal | scalar | *Visual     | NONE | <b>NONE</b>  | NONE | NONE |

## CONTAMINATION













There is no indication of any contamination in the oil.

|                  |          |             |       |                |       |       |
|------------------|----------|-------------|-------|----------------|-------|-------|
| Silicon          | ppm      | ASTM D5185m | >200  | <b>186</b>     | 165   | 138   |
| Potassium        | ppm      | ASTM D5185m | >20   | <b>1</b>       | 1     | 1     |
| Fuel             |          | WC Method   | >4.0  | <b>&lt;1.0</b> | <1.0  | <1.0  |
| Water            |          | WC Method   | >0.1  | <b>NEG</b>     | NEG   | NEG   |
| Glycol           |          | WC Method   |       | <b>NEG</b>     | NEG   | NEG   |
| Soot %           | %        | *ASTM D7844 |       | <b>0</b>       | 0     | 0     |
| Nitration        | Abs/cm   | *ASTM D7624 | >20   | <b>6.4</b>     | 6.1   | 5.9   |
| Sulfation        | Abs/.1mm | *ASTM D7415 | >30   | <b>19.9</b>    | 19.3  | 18.8  |
| Silt             | scalar   | *Visual     | NONE  | <b>NONE</b>    | NONE  | NONE  |
| Debris           | scalar   | *Visual     | NONE  | <b>NONE</b>    | NONE  | NONE  |
| Sand/Dirt        | scalar   | *Visual     | NONE  | <b>NONE</b>    | NONE  | NONE  |
| Appearance       | scalar   | *Visual     | NORML | <b>NORML</b>   | NORML | NORML |
| Odor             | scalar   | *Visual     | NORML | <b>NORML</b>   | NORML | NORML |
| Emulsified Water | scalar   | *Visual     | >0.1  | <b>NEG</b>     | NEG   | NEG   |

## FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

|                  |          |             |     |              |      |      |
|------------------|----------|-------------|-----|--------------|------|------|
| Sodium           | ppm      | ASTM D5185m |     | <b>0</b>     | 1    | 2    |
| Boron            | ppm      | ASTM D5185m |     | <b>3</b>     | 4    | 4    |
| Barium           | ppm      | ASTM D5185m |     | <b>&lt;1</b> | 0    | 0    |
| Molybdenum       | ppm      | ASTM D5185m |     | <b>6</b>     | 6    | 5    |
| Manganese        | ppm      | ASTM D5185m |     | <b>&lt;1</b> | <1   | <1   |
| Magnesium        | ppm      | ASTM D5185m |     | <b>25</b>    | 29   | 30   |
| Calcium          | ppm      | ASTM D5185m |     | <b>1461</b>  | 1419 | 1395 |
| Phosphorus       | ppm      | ASTM D5185m |     | <b>362</b>   | 308  | 334  |
| Zinc             | ppm      | ASTM D5185m |     | <b>442</b>   | 430  | 426  |
| Sulfur           | ppm      | ASTM D5185m |     | <b>3180</b>  | 2792 | 3197 |
| Oxidation        | Abs/.1mm | *ASTM D7414 | >25 | <b>15.9</b>  | 14.8 | 14.1 |
| Acid Number (AN) | mg KOH/g | ASTM D8045  |     | <b>1.86</b>  | 1.58 | 1.52 |
| Base Number (BN) | mg KOH/g | ASTM D2896  |     | <b>3.18</b>  | 3.16 | 3.78 |
| Visc @ 100°C     | cSt      | ASTM D445   |     | <b>13.7</b>  | 13.6 | 13.4 |



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0909645  
**Lab Number** : 06146045  
**Unique Number** : 10976123  
**Test Package** : MOB 2

**Received** : 11 Apr 2024  
**Tested** : 12 Apr 2024  
**Diagnosed** : 15 Apr 2024 - Don Baldrige

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**BROOME ENERGY**  
 286 KNAPP ROAD  
 BINGHAMTON, NY  
 US 13905

Contact: RUSS MERCER  
 BroomeEnergy@gmail.com  
 T: (607)766-0358  
 F: (607)766-0357