

## WCLSNC Machine Id QC COOL ELC NC 09012022 Component Coolant

## CAT EXTENDED LIFE COOLANT (ELC) (--- GAL)

The fluid is suitable

RECOMMENDATION	
No corrective action is recommen-	ded at this time.
for further service.	

All metal levels are normal indicating no corrosion in the cooling system.

## CONTAMINANTS


There is no indication of any contamination in the coolant.


. . . . . . . . .

## COOLANT CONDITION

Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

)						
Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0929335	WC0929334	WC0929333
Sample Date		Client Info		11 Apr 2024	10 Apr 2024	09 Apr 2024
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	SEVERE	NORMAL
Iron	ppm	ASTM D6130	>2	<1	0	0
Aluminum	ppm	ASTM D6130	>2	0	0	0
Copper	ppm	ASTM D6130	>2	<1	<1	<1
Lead	ppm	ASTM D6130	>2	0	<1	<1
Tin	ppm	ASTM D6130	>2	0	<1	<1
Zinc	ppm	ASTM D6130	>10	0	<1	<1
Calcium	ppm	ASTM D6130	>5	0	0	0
Chlorine	ppm	ASTM D6130		0	2	<1
Magnesium	ppm	ASTM D6130	>6	0	0	0
Total Dissolved Solids				295.5	331.0	370.0
Coolant Appearance		*Visual	Clear	normal	normal	normal
Boiling Point	°C	WC Method		225	225	225
Specific Gravity		*ASTM D1298		1.067	1.067	1.067
pН	Scale 0-14	ASTM D1287		8.33	8.32	8.43
Nitrites	ppm	AP-053:2009		712	824	712
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		49.3	49.4	49.2
Freezing Point	°F	ASTM D3321		-33	-33	-33
Carboxylate				fail	🔺 fail	pass
Silicon	ppm	ASTM D6130	0	1	1	2
Phosphorus	ppm	ASTM D6130	0	0	8	0
Boron	ppm	ASTM D6130	0	0	0	0
Molybdenum	ppm	ASTM D6130	950	694	<b>~</b> 744	769
Sodium	ppm	ASTM D6130		4135	4340	4503
Potassium	ppm	ASTM D6130		3	34	4
Coolant Color		*Visual		Red	Red	Red





: WearCheck USA - 501 Madison Ave., Cary, NC 27513 WEARCHECK LUBRICATION SERVICES QA ACCOUNT Laboratory Sample No. : WC0929335 Received 501 Madison Ave : 11 Apr 2024 Lab Number : 06146290 Tested : 16 Apr 2024 Cary, NC Unique Number : 10976368 Diagnosed : 16 Apr 2024 - Jonathan Hester US 27513 Test Package : COOL- ( Additional Tests: BoilingPoint, COOL, GlycolType, ICP ) Contact: WCLS CARY NC Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (919)379-4102 F: (919)379-4050 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)