

CORROSION
CONTAMINANTS
COOLANT CONDITION

NORMAL NORMAL


5C07


RTR9951 REEFER (S/N 1GRAA064XJB704889)

Component Coolant

CONVENTIONAL COOLANT (--- GAL)

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service.	Sample Number		Client Info		ARI06147925	ARI014362	
	Sample Date		Client Info		11 Apr 2024	15 Jan 2020	
	Machine Age	hrs	Client Info		13883	3491	
	Oil Age	hrs	Client Info		0	0	
	Oil Changed		Client Info		N/A	N/A	
	Sample Status				NORMAL	NORMAL	
CORROSION	Total Dissolved Solids				279.0	326.5	
	Coolant Appearance		*Visual	Clear	normal	normal	
CONTAMINANTS	Boiling Point	°C	WC Method		225		
There is no indication of any contamination in the coolant.	Specific Gravity		*ASTM D1298		1.068		
	рН	Scale 0-14	ASTM D1287		7.77	7.61	
	Nitrites	ppm	AP-053:2009		824	412	
	Reserve Alkalinity	Scale 0-20	*ASTM D1121				
	Percentage Glycol	%	ASTM D3321		50.6	50	
	Freezing Point	°F	ASTM D3321		-35	-37	
	Carboxylate				n/a	n/a	
	Coolant Color		*Visual		Pink	Pink	







Laboratory Sample No.

Lab Number : 06147925

Unique Number : 10978003

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : ARI06147925 Received : 12 Apr 2024 **Tested** : 16 Apr 2024

Diagnosed : 16 Apr 2024 - Jonathan Hester Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. **INSITUFORM TECHNOLOGIES, INC**

17988 EDISON AVE. CHESTERFIELD, MO US 63005

Contact: WILLIAM COWELL WCOWELL@INSITUFORM.COM

T: (317)450-3774

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)