



FUEL REPORT

CORROSION	NORMAL
CONTAMINANTS	NORMAL
FUEL CONDITION	NORMAL

Area

[PMI2783665]

Machine Id

SD100 3008738131

Component

Tank Diesel Fuel

Fluid

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

RECOMMENDATION

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

CORROSION

All metal levels are normal indicating no corrosion in the system.




CONTAMINANTS

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel.

FUEL CONDITION

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		DC0035914	DC0023529	DC0019302
Sample Date		Client Info		01 Apr 2024	13 Apr 2023	06 Apr 2022
Machine Age	hrs	Client Info		56	36	15
Sample Status				NORMAL	NORMAL	NORMAL
Aluminum	ppm	ASTM D5185m	<0.1	0	0	0
Nickel	ppm	ASTM D5185m	<0.1	0	0	0
Lead	ppm	ASTM D5185m	<0.1	0	<1	0
Vanadium	ppm	ASTM D5185m	<0.1	0	0	0
Iron	ppm	ASTM D5185m	<0.1	0	0	0
Silicon	ppm	ASTM D5185m	<1.0	2	0	<1
Sodium	ppm	ASTM D5185m	<0.1	<1	0	0
Potassium	ppm	ASTM D5185m	<0.1	0	<1	0
Water	%	ASTM D6304	<0.05	0.003	0.003	0.002
ppm Water	ppm	ASTM D6304	<500	37	27.7	20.2
Particles >4µm		ASTM D7647	>2500	---	---	1275
Particles >6µm		ASTM D7647	>640	---	---	273
Particles >14µm		ASTM D7647	>80	---	---	15
Particles >21µm		ASTM D7647	>20	---	---	3
Particles >38µm		ASTM D7647	>4	---	---	0
Particles >71µm		ASTM D7647	>3	---	---	0
Oil Cleanliness		ISO 4406 (c)	>18/16/13	---	---	17/15/11
% Gasoline	%	*In-House	<0.50	0.0	0.0	0.0
% Biodiesel	%	*In-House	<20.0	0.0	0.0	0.0
Calcium	ppm	ASTM D5185m	<0.1	4	0	0
Magnesium	ppm	ASTM D5185m	<0.1	0	<1	0
Phosphorus	ppm	ASTM D5185m	<0.1	0	4	7
Zinc	ppm	ASTM D5185m	<0.1	0	0	0
ASTM Color	scalar	*ASTM D1500		L4.5	4.0	4.0
Visc @ 40°C	cSt	ASTM D445	3.0	2.5	2.46	2.46
Sulfur	ppm	ASTM D5185m	10	0	2	0
Sulfur (UVF)	ppm	ASTM D5453		13	8	8
API Gravity		ASTM D7777	37.7	36.5	37.2	37.1



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0035914
Lab Number : 06149224
Unique Number : 10979302
Test Package : DF-5 (Additional Tests: API, Cetane, Fuel, PrtCount, Screen)

Received : 15 Apr 2024
Tested : 26 Apr 2024
Diagnosed : 26 Apr 2024 - Angela Borella

KELLY GENERATOR & EQUIPMENT INC
 1955 DALE LN
 OWINGS, MD
 US 20736
 Contact: LESLIE SNURR
 LSNURR@KGE.COM
 T: (410)257-5225
 F: (410)257-5227

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)