



COOLANT REPORT

CORROSION	NORMAL
CONTAMINANTS	NORMAL
COOLANT CONDITION	NORMAL

Area
[PMOAS3218947]
 Machine Id
P0709240003 - 4017019
 Component
Coolant
 Fluid
HYBRID (HOAT) COOLANT (--- GAL)

RECOMMENDATION

The fluid is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		DC0035286	DC0021488	DCM1024194
Sample Date		Client Info		29 Mar 2024	05 May 2022	21 Jul 2016
Machine Age	mls	Client Info		323	0	0
Oil Age	mls	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL








CORROSION

Total Dissolved Solids				427.0	395.0	550
Coolant Appearance		*Visual	Clear	normal	normal	normal

CONTAMINANTS

There is no indication of any contamination in the coolant.

Boiling Point	°C	WC Method		227	---	---
Specific Gravity		*ASTM D1298		1.074	1.070	---
pH	Scale 0-14	ASTM D1287		7.65	8.17	9.30
Nitrites	ppm	AP-053:2009		788	864	1120
Reserve Alkalinity	Scale 0-20	*ASTM D1121		---	---	---
Percentage Glycol	%	ASTM D3321		55.4	52.6	48
Freezing Point	°F	ASTM D3321		-47	-40	-34
Carboxylate				n/a	n/a	n/a
Coolant Color		*Visual		Yllow	Yllow	Yllow



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0035286 **Received** : 17 Apr 2024
Lab Number : 06152485 **Tested** : 18 Apr 2024
Unique Number : 10982563 **Diagnosed** : 22 Apr 2024 - Jonathan Hester
Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

KELLY GENERATOR & EQUIPMENT INC
 1955 DALE LN
 OWINGS, MD
 US 20736
 Contact: LESLIE SNURR
 LSNURR@KGE.COM
 T: (410)257-5225
 F: (410)257-5227

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)