



COOLANT REPORT

CORROSION	NORMAL
CONTAMINANTS	NORMAL
COOLANT CONDITION	NORMAL

Area
[PMOAS3372450]
 Machine Id
SD60 SHELL HORN RD (S/N 3001702962)
 Component
Coolant
 Fluid
HYBRID (HOAT) COOLANT (--- GAL)

RECOMMENDATION

The fluid is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		DC0034963	DC0028837	DC0019187
Sample Date		Client Info		08 Apr 2024	03 Apr 2023	18 Apr 2022
Machine Age	hrs	Client Info		0	106	84
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	Not Changd	Changed
Sample Status				NORMAL	NORMAL	NORMAL








CORROSION

Total Dissolved Solids				266.5	479.5	490.0
Coolant Appearance		*Visual	Clear	normal	normal	normal

CONTAMINANTS

There is no indication of any contamination in the coolant.

Boiling Point	°C	WC Method		225	---	---
Specific Gravity		*ASTM D1298		1.068	1.069	1.069
pH	Scale 0-14	ASTM D1287		8.84	7.55	7.56
Nitrites	ppm	AP-053:2009		600	1276	1200
Reserve Alkalinity	Scale 0-20	*ASTM D1121		---	---	---
Percentage Glycol	%	ASTM D3321		50.6	51.4	51.2
Freezing Point	°F	ASTM D3321		-35	-38	-38
Carboxylate				n/a	n/a	n/a
Coolant Color		*Visual		Yllow	Yllow	Yllow



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0034963
Lab Number : 06152492
Unique Number : 10982570
Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

KELLY GENERATOR & EQUIPMENT INC
 1955 DALE LN
 OWINGS, MD
 US 20736
 Contact: LESLIE SNURR
 LSNURR@KGE.COM
 T: (410)257-5225
 F: (410)257-5227

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)