CORROSION CONTAMINANTS COOLANT CONDITION

NORMAL NORMAL NORMAL


[PMOAS3372452]


1D6C200-2M P1306180005

Component Coolant

CONVENTIONAL COOLANT (--- QTS)

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service.	Sample Number		Client Info		DC0034956	DC0020393	DC0010831
	Sample Date		Client Info		09 Apr 2024	08 Jun 2023	26 Apr 2021
	Machine Age	hrs	Client Info		62	0	0
	Oil Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		N/A	N/A	N/A
	Sample Status				NORMAL	NORMAL	NORMAL
CORROSION	Total Dissolved Solids				254.5	254.5	325.5
	Coolant Appearance		*Visual	Clear	normal	normal	normal
CONTAMINANTS	Boiling Point	°C	WC Method		225		
There is no indication of any contamination in the coolant.	Specific Gravity		*ASTM D1298		1.065	1.066	
	рН	Scale 0-14	ASTM D1287		9.43	9.69	9.25
	Nitrites	ppm	AP-053:2009		1500	1428	1464
	Reserve Alkalinity	Scale 0-20	*ASTM D1121				
	Percentage Glycol	%	ASTM D3321		48.6	48.8	49
	Freezing Point	°F	ASTM D3321		-31	-31	-35
	Carboxylate				n/a	n/a	n/a
	Coolant Color		*Visual		Pink	Pink	Pink







Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No.

Lab Number : 06152496

Unique Number : 10982574

: DC0034956 Received **Tested**

Diagnosed To discuss this sample report, contact Customer Service at 1-800-237-1369.

: 18 Apr 2024 : 23 Apr 2024 - Jonathan Hester Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

: 17 Apr 2024

KELLY GENERATOR & EQUIPMENT INC 1955 DALE LN OWINGS, MD US 20736 Contact: LESLIE SNURR

LSNURR@KGE.COM T: (410)257-5225

F: (410)257-5227

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: LESLIE SNURR - KELOWI