

Machine Id GWYNETH ANNE Component Starboard Genset Filuid DIESEL ENGINE OIL SAE 40 (--- GAL)

RECOMMENDATION

Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) DIESEL ENGINE OIL SAE 40. Please confirm. Please specify the component make and model with your next sample.

WEAR

All component wear rates are normal.


CONTAMINATION

There is no indication of any contamination in the oil.

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		LW0008471		
Sample Date		Client Info		29 Mar 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		1000		
Filter Age	hrs	Client Info		1000		
Oil Changed		Client Info		Changed		
Filter Changed		Client Info		Changed		
Sample Status				NORMAL		
Iron	ppm	ASTM D5185m	>50	15		
Chromium	ppm	ASTM D5185m	>4	1		
Nickel	ppm	ASTM D5185m	>2	1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m	>5	<1		
Aluminum	ppm	ASTM D5185m	>12	2		
Lead	ppm	ASTM D5185m	>17	4		
Copper	ppm	ASTM D5185m	>70	1		
Tin	ppm	ASTM D5185m	>15	1		
Vanadium	ppm	ASTM D5185m		<1		
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Silicon	0000	ASTM D5185m	>25	5		
Potassium	ppm		>20	э 1		
Fuel	ppm	ASTM D5185m	>20	-		
Water		WC Method	>4.0	<1.0 NEG		
		WC Method	>0.1	NEG		
Glycol Soot %	%	*ASTM D7844		0.3		
Nitration	Abs/cm	*ASTM D7624	>20	6.9		
Sulfation	Abs/.1mm	*ASTM D7024	>30	19.1		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water		*Visual	>0.1	NEG		
Sodium	ppm	ASTM D5185m	>216	2		
Boron	ppm	ASTM D5185m	250	8		
Barium	ppm	ASTM D5185m	10	0		
Molybdenum	ppm	ASTM D5185m	100	64		
Manganese	ppm	ASTM D5185m		1		
Magnesium	ppm	ASTM D5185m	450	943		
Calcium	ppm	ASTM D5185m	3000	1119		
Phosphorus	ppm	ASTM D5185m	1150	1123		
Zinc	ppm	ASTM D5185m	1350	1270		
Sulfur	ppm	ASTM D5185m	4250	3444		
Oxidation	Abs/.1mm	*ASTM D7414	>25	14.8		
Base Number (BN)	mg KOH/g	ASTM D2896	8.5	8.8		
Visc @ 100°C	cSt	ASTM D445	14.4	13.9		



Lab Number : 06152721 Tested : 18 Apr 2024 Unique Number : 10982799 Diagnosed : 18 Apr 2024 - Wes Davis US 60448 Test Package : MOB 1 (Additional Tests: TBN) Contact: JENNIFER DOROSZ Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. jenniferdorosz@gomiddleriver.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: