

## Machine Id GWYNETH ANNE Component Port Genset Fluid DIESEL ENGINE OIL SAE 40 (--- GAL)

## RECOMMENDATION

Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) DIESEL ENGINE OIL SAE 40. Please confirm. Please specify the component make and model with your next sample.

WEAR

All component wear rates are normal.

## CONTAMINATION

There is no indication of any contamination in the oil.

## **FLUID CONDITION**

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		LW0008472		
Sample Date		Client Info		29 Mar 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		1000		
Filter Age	hrs	Client Info		1000		
Oil Changed		Client Info		Changed		
Filter Changed		Client Info		Changed		
Sample Status				NORMAL		
Iron	ppm	ASTM D5185m	>50	12		
Chromium	ppm	ASTM D5185m	>4	1		
Nickel	ppm	ASTM D5185m	>2	1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m	>5	<1		
Aluminum	ppm	ASTM D5185m	>12	2		
Lead	ppm	ASTM D5185m	>17	4		
Copper	ppm	ASTM D5185m	>70	1		
Tin	ppm	ASTM D5185m	>15	1		
Vanadium	ppm	ASTM D5185m		<1		
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
				•		
Silicon	ppm	ASTM D5185m	>25	6		
Potassium	ppm	ASTM D5185m	>20	2		
Fuel		WC Method	>4.0	<1.0		
Water		WC Method	>0.1	NEG		
Glycol		WC Method		NEG		
Soot %	%	*ASTM D7844		0.2		
Nitration	Abs/cm	*ASTM D7624	>20	7.0		
Sulfation	Abs/.1mm	*ASTM D7415	>30	19.1		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Sodium	nom	ASTM D5185m	>216	2		
Boron	ppm	ASTM D5185m		5		
	ppm	ASTM D5185m ASTM D5185m				
Barium	ppm	ASTM D5185m ASTM D5185m	10 100	0 68		
Molybdenum	ppm		100	08 1		
Manganese	ppm	ASTM D5185m	450			
Magnesium Calcium	ppm	ASTM D5185m	450 3000	960 1102		
	ppm	ASTM D5185m				
Phosphorus	ppm	ASTM D5185m	1150	1035		
Zinc	ppm	ASTM D5185m	1350	1236		
Sulfur	ppm	ASTM D5185m	4250	3027		
Oxidation	Abs/.1mm	*ASTM D7414	>25	14.9		
Base Number (BN)	mg KOH/g	ASTM D2896	8.5	8.6		
Visc @ 100°C	cSt	ASTM D445	14.4	13.8		



Lab Number : 06152722 Tested MOKENA, IL : 18 Apr 2024 Unique Number : 10982800 Diagnosed : 18 Apr 2024 - Wes Davis US 60448 Test Package : MOB 1 (Additional Tests: TBN) Contact: JENNIFER DOROSZ Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. jenniferdorosz@gomiddleriver.com \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Submitted By: JEFFREY CAGWIN Page 2 of 2

T:

F: