



FUEL REPORT

CORROSION	NORMAL
CONTAMINANTS	ABNORMAL
FUEL CONDITION	NORMAL

Machine Id
KIOTI CK3510 TP9400510

Component
Diesel Fuel

Fluid
No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

RECOMMENDATION

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		KT0000899	---	---
Sample Date		Client Info		16 Apr 2024	---	---
Machine Age	hrs	Client Info		2654	---	---
Sample Status				ABNORMAL	---	---

CORROSION

All metal levels are normal indicating no corrosion in the cooling system.

Aluminum	ppm	ASTM D5185m	<0.1	0	---	---
Nickel	ppm	ASTM D5185m	<0.1	0	---	---
Lead	ppm	ASTM D5185m	<0.1	0	---	---
Vanadium	ppm	ASTM D5185m	<0.1	<1	---	---
Iron	ppm	ASTM D5185m	<0.1	0	---	---

CONTAMINANTS









There is a high amount of particulates present in the fuel. The water content is negligible.

Silicon	ppm	ASTM D5185m	<1.0	0	---	---
Sodium	ppm	ASTM D5185m	<0.1	0	---	---
Potassium	ppm	ASTM D5185m	<0.1	0	---	---
Water	%	ASTM D6304	<0.05	0.003	---	---
ppm Water	ppm	ASTM D6304	<500	27	---	---
Particles >4µm		ASTM D7647	>2500	▲ 9298	---	---
Particles >6µm		ASTM D7647	>640	▲ 4092	---	---
Particles >14µm		ASTM D7647	>80	▲ 505	---	---
Particles >21µm		ASTM D7647	>20	▲ 112	---	---
Particles >38µm		ASTM D7647	>4	2	---	---
Particles >71µm		ASTM D7647	>3	0	---	---
Oil Cleanliness		ISO 4406 (c)	>18/16/13	▲ 20/19/16	---	---
% Gasoline	%	*In-House	<0.50	0.0	---	---
% Biodiesel	%	*In-House	<20.0	0.0	---	---
Calcium	ppm	ASTM D5185m	<0.1	<1	---	---
Magnesium	ppm	ASTM D5185m	<0.1	0	---	---
Phosphorus	ppm	ASTM D5185m	<0.1	0	---	---
Zinc	ppm	ASTM D5185m	<0.1	0	---	---

FUEL CONDITION

All laboratory tests indicate that this sample meets specifications for No.2 diesel fuel, low sulfur (US EPA/CGSB-3.517-3 type B). Sulfur level is acceptable for ULSD specification.

ASTM Color	scalar	*ASTM D1500		L1.0	---	---
Visc @ 40°C	cSt	ASTM D445	3.0	2.42	---	---
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	59	---	---
Sulfur	ppm	ASTM D5185m	10	0	---	---
Sulfur (UVF)	ppm	ASTM D5453		10	---	---
Initial Boiling Point	°C	ASTM D86	165	169	---	---
10% Distill Point	°C	ASTM D86	201	201	---	---
20% Distill Point	°C	ASTM D86	216	217	---	---
30% Distill Point	°C	ASTM D86	230	232	---	---
40% Distill Point	°C	ASTM D86	243	245	---	---
50% Distill Point	°C	ASTM D86	255	259	---	---
60% Distill Point	°C	ASTM D86	267	273	---	---
70% Distill Point	°C	ASTM D86	280	286	---	---
80% Distill Point	°C	ASTM D86	295	302	---	---
90% Distill Point	°C	ASTM D86	310	323	---	---
Final Boiling Point	°C	ASTM D86	341	354	---	---
API Gravity		ASTM D7777	37.7	37	---	---
Cetane Index		ASTM D4737	<40.0	48	---	---



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KT0000899
Lab Number : 06153865
Unique Number : 10989288
Test Package : DF-2 (Additional Tests: Fuel, Screen)

Received : 18 Apr 2024
Tested : 30 Apr 2024
Diagnosed : 30 Apr 2024 - Angela Borella

SUWANEE EQUIPMENT
 3869 US 129N
 LIVE OAK, FL
 US 32060
 Contact: SHAINÉ
 SHAINÉ628@GMAIL.COM
 T: (386)364-7081
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)