



Area  
**CGL**  
Machine Id  
**CGL**  
Component  
**Port Genset**  
Fluid  
**CHEVRON DELO 710 LS (5 GAL)**

**RECOMMENDATION**

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>MW0050823</b>	MW0050821	MW0061109
Sample Date		Client Info		<b>12 Apr 2024</b>	10 Mar 2024	24 Feb 2024
Machine Age	hrs	Client Info		<b>23450</b>	23136	22860
Oil Age	hrs	Client Info		<b>338</b>	226	305
Filter Age	hrs	Client Info		<b>338</b>	226	305
Oil Changed		Client Info		<b>Changed</b>	Changed	Changed
Filter Changed		Client Info		<b>Changed</b>	Changed	Changed
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

**WEAR**

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>50	<b>4</b>	5	6
Chromium	ppm	ASTM D5185m	>4	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185m	>2	<b>0</b>	<1	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	<1	<1
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>12	<b>1</b>	2	2
Lead	ppm	ASTM D5185m	>17	<b>&lt;1</b>	<1	<1
Copper	ppm	ASTM D5185m	>70	<b>&lt;1</b>	<1	1
Tin	ppm	ASTM D5185m	>15	<b>&lt;1</b>	<1	<1
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE

**CONTAMINATION**








There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>25	<b>2</b>	4	4
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	4	4
Fuel		WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Water		WC Method	>0.1	<b>NEG</b>	NEG	NEG
Glycol		WC Method		<b>NEG</b>	NEG	NEG
Soot %	%	*ASTM D7844		<b>0.1</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	<b>7.5</b>	7.1	7.3
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>14.8</b>	14.2	13.9
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	<b>NEG</b>	NEG	NEG

**FLUID CONDITION**

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		<b>9</b>	79	80
Boron	ppm	ASTM D5185m		<b>41</b>	41	42
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>44</b>	46	44
Manganese	ppm	ASTM D5185m		<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>9</b>	8	9
Calcium	ppm	ASTM D5185m		<b>3289</b>	3184	3187
Phosphorus	ppm	ASTM D5185m		<b>0</b>	3	4
Zinc	ppm	ASTM D5185m		<b>0</b>	<1	2
Sulfur	ppm	ASTM D5185m		<b>2394</b>	1937	2111
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>9.0</b>	8.5	8.2
Base Number (BN)	mg KOH/g	ASTM D2896	10.5	<b>6.1</b>	6.2	6.5
Visc @ 100°C	cSt	ASTM D445	15.5	<b>14.3</b>	14.2	14.4



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : MW0050823  
**Lab Number** : 06153955  
**Unique Number** : 10989378  
**Test Package** : MAR 2

**Received** : 19 Apr 2024  
**Tested** : 22 Apr 2024  
**Diagnosed** : 22 Apr 2024 - Wes Davis

**AMERICAN RIVER TRANSPORTATION CO.**  
 P.O. BOX 2889  
 ST. LOUIS, MO  
 US 63111  
 Contact: BRIAN GRIEWING  
 brian.griewing@adm.com  
 T:  
 F: (314)481-5278

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)