



# OIL ANALYSIS REPORT

WEAR	<b>NORMAL</b>
CONTAMINATION	<b>SEVERE</b>
FLUID CONDITION	<b>ABNORMAL</b>

Machine Id  
**INTERNATIONAL 2582**  
Component  
**Diesel Engine**  
Fluid  
**DIESEL ENGINE OIL SAE 15W40 (--- QTS)**

## RECOMMENDATION

We advise that you check the fuel injection system. The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>RW0005070</b>	RW0005144	RW0004934
Sample Date		Client Info		<b>26 Mar 2024</b>	14 Feb 2024	31 Jan 2024
Machine Age	mls	Client Info		<b>165229</b>	161299	159590
Oil Age	mls	Client Info		<b>5600</b>	2500	6000
Filter Age	mls	Client Info		<b>5600</b>	2500	6000
Oil Changed		Client Info		<b>Changed</b>	Not Changd	Changed
Filter Changed		Client Info		<b>Changed</b>	Not Changed	Changed
Sample Status				<b>SEVERE</b>	MARGINAL	SEVERE

## WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>100	<b>17</b>	7	6
Chromium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m	>4	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m		<b>0</b>	<1	0
Silver	ppm	ASTM D5185m	>3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>20	<b>2</b>	1	2
Lead	ppm	ASTM D5185m	>40	<b>&lt;1</b>	0	1
Copper	ppm	ASTM D5185m	>330	<b>1</b>	<1	<1
Tin	ppm	ASTM D5185m	>15	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE

## CONTAMINATION













There is a high amount of fuel present in the oil. Tests confirm the presence of fuel in the oil.

Silicon	ppm	ASTM D5185m	>25	<b>6</b>	4	2
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	0	<1
Fuel	%	ASTM D3524	>5	<b>▲ 9.4</b>	▲ 4.9	▲ 10.3
Water		WC Method	>0.2	<b>NEG</b>	NEG	NEG
Glycol		WC Method		<b>NEG</b>	NEG	NEG
Soot %	%	*ASTM D7844	>3	<b>0.5</b>	0.2	0.4
Nitration	Abs/cm	*ASTM D7624	>20	<b>11.3</b>	7.2	9.7
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>21.0</b>	18.9	19.8
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	<b>NEG</b>	NEG	NEG

## FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. Fuel is present in the oil and is lowering the viscosity. The oil is no longer serviceable due to the presence of contaminants.

Sodium	ppm	ASTM D5185m	>158	<b>1</b>	<1	<1
Boron	ppm	ASTM D5185m	250	<b>0</b>	4	5
Barium	ppm	ASTM D5185m	10	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	100	<b>53</b>	54	49
Manganese	ppm	ASTM D5185m		<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m	450	<b>799</b>	896	737
Calcium	ppm	ASTM D5185m	3000	<b>989</b>	984	817
Phosphorus	ppm	ASTM D5185m	1150	<b>868</b>	994	798
Zinc	ppm	ASTM D5185m	1350	<b>966</b>	1172	969
Sulfur	ppm	ASTM D5185m	4250	<b>2925</b>	3062	2366
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>20.5</b>	15.3	19.2
Base Number (BN)	mg KOH/g	ASTM D2896	8.5	<b>7.52</b>	9.37	8.14
Visc @ 100°C	cSt	ASTM D445	14.4	<b>▲ 11.5</b>	12.7	▲ 11.7



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RW0005070 **Received** : 19 Apr 2024  
**Lab Number** : 06154659 **Tested** : 23 Apr 2024  
**Unique Number** : 10990082 **Diagnosed** : 23 Apr 2024 - Wes Davis  
**Test Package** : MOB 2 ( Additional Tests: FuelDilution, PercentFuel )

**NEWKIRK ELECTRIC**  
 1875 ROBERTS ST.  
 MUSKEGON, MI  
 US 49442  
 Contact: ERIC KING  
 ewking@newkirk-electric.com  
 T: (231)206-6131  
 F: (231)724-4090

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)