



COOLANT REPORT

CORROSION	NORMAL
CONTAMINANTS	NORMAL
COOLANT CONDITION	NORMAL

Area
[PMO2112796966]

Machine Id
8470195

Component
Coolant

Fluid
EXTENDED LIFE COOLANT (--- QTS)

RECOMMENDATION

The fluid is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		DC0028707	---	---
Sample Date		Client Info		11 Apr 2024	---	---
Machine Age	hrs	Client Info		223	---	---
Oil Age	hrs	Client Info		20	---	---
Oil Changed		Client Info		Changed	---	---
Sample Status				NORMAL	---	---







CORROSION

Total Dissolved Solids				183.5	---	---
Coolant Appearance		*Visual	Clear	normal	---	---

CONTAMINANTS

There is no indication of any contamination in the coolant.

Boiling Point	°C	WC Method		225	---	---
Specific Gravity		*ASTM D1298		1.066	---	---
pH	Scale 0-14	ASTM D1287		8.76	---	---
Nitrites	ppm	AP-053:2009		1464	---	---
Reserve Alkalinity	Scale 0-20	*ASTM D1121		---	---	---
Percentage Glycol	%	ASTM D3321		48.9	---	---
Freezing Point	°F	ASTM D3321		-31	---	---
Carboxylate				n/a	---	---
Coolant Color		*Visual		Red	---	---



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0028707 **Received** : 19 Apr 2024
Lab Number : 06155032 **Tested** : 22 Apr 2024
Unique Number : 10990455 **Diagnosed** : 24 Apr 2024 - Jonathan Hester
Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

KELLY GENERATOR & EQUIPMENT INC
 1955 DALE LN
 OWINGS, MD
 US 20736
 Contact: LESLIE SNURR
 LSNURR@KGE.COM
 T: (410)257-5225
 F: (410)257-5227

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)