

Machine Id
1013
Component
Front Gasoline Engine
Fluid
PETRO CANADA SUPREME SYNTHETIC 0W20 (7 QTS)

RECOMMENDATION

Resample at the next service interval to monitor.

| Test | UOM | Method | Limit/Abn | Current | History1 | History2 |
|----------------|-----|-------------|-----------|--------------------|----------|----------|
| Sample Number | | Client Info | | PCA0109985 | --- | --- |
| Sample Date | | Client Info | | 16 Apr 2024 | --- | --- |
| Machine Age | mls | Client Info | | 45781 | --- | --- |
| Oil Age | mls | Client Info | | 6000 | --- | --- |
| Filter Age | mls | Client Info | | 6000 | --- | --- |
| Oil Changed | | Client Info | | Changed | --- | --- |
| Filter Changed | | Client Info | | Changed | --- | --- |
| Sample Status | | | | NORMAL | --- | --- |

WEAR

All component wear rates are normal.

| | | | | | | |
|--------------|--------|-------------|------|--------------|-----|-----|
| Iron | ppm | ASTM D5185m | >150 | 13 | --- | --- |
| Chromium | ppm | ASTM D5185m | >20 | <1 | --- | --- |
| Nickel | ppm | ASTM D5185m | >5 | <1 | --- | --- |
| Titanium | ppm | ASTM D5185m | | <1 | --- | --- |
| Silver | ppm | ASTM D5185m | >2 | 0 | --- | --- |
| Aluminum | ppm | ASTM D5185m | >40 | 2 | --- | --- |
| Lead | ppm | ASTM D5185m | >50 | <1 | --- | --- |
| Copper | ppm | ASTM D5185m | >155 | 22 | --- | --- |
| Tin | ppm | ASTM D5185m | >10 | <1 | --- | --- |
| Vanadium | ppm | ASTM D5185m | | 0 | --- | --- |
| White Metal | scalar | *Visual | NONE | NONE | --- | --- |
| Yellow Metal | scalar | *Visual | NONE | NONE | --- | --- |

CONTAMINATION













There is no indication of any contamination in the oil.

| | | | | | | |
|------------------|----------|-------------|-------|----------------|-----|-----|
| Silicon | ppm | ASTM D5185m | >30 | 9 | --- | --- |
| Potassium | ppm | ASTM D5185m | >20 | 3 | --- | --- |
| Fuel | | WC Method | >4.0 | <1.0 | --- | --- |
| Water | | WC Method | >0.2 | NEG | --- | --- |
| Glycol | | WC Method | | NEG | --- | --- |
| Soot % | % | *ASTM D7844 | | 0 | --- | --- |
| Nitration | Abs/cm | *ASTM D7624 | >20 | 7.3 | --- | --- |
| Sulfation | Abs/.1mm | *ASTM D7415 | >30 | 18.1 | --- | --- |
| Silt | scalar | *Visual | NONE | NONE | --- | --- |
| Debris | scalar | *Visual | NONE | NONE | --- | --- |
| Sand/Dirt | scalar | *Visual | NONE | NONE | --- | --- |
| Appearance | scalar | *Visual | NORML | NORML | --- | --- |
| Odor | scalar | *Visual | NORML | NORML | --- | --- |
| Emulsified Water | scalar | *Visual | >0.2 | NEG | --- | --- |

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

| | | | | | | |
|------------------|----------|-------------|------|--------------|-----|-----|
| Sodium | ppm | ASTM D5185m | >400 | <1 | --- | --- |
| Boron | ppm | ASTM D5185m | 230 | 149 | --- | --- |
| Barium | ppm | ASTM D5185m | 0 | 0 | --- | --- |
| Molybdenum | ppm | ASTM D5185m | 74 | 73 | --- | --- |
| Manganese | ppm | ASTM D5185m | 0 | <1 | --- | --- |
| Magnesium | ppm | ASTM D5185m | 556 | 487 | --- | --- |
| Calcium | ppm | ASTM D5185m | 1293 | 1245 | --- | --- |
| Phosphorus | ppm | ASTM D5185m | 833 | 656 | --- | --- |
| Zinc | ppm | ASTM D5185m | 808 | 762 | --- | --- |
| Sulfur | ppm | ASTM D5185m | 2676 | 2734 | --- | --- |
| Oxidation | Abs/.1mm | *ASTM D7414 | >25 | 10.9 | --- | --- |
| Base Number (BN) | mg KOH/g | ASTM D2896 | 7.1 | 5.97 | --- | --- |
| Visc @ 100°C | cSt | ASTM D445 | 8.3 | 8.1 | --- | --- |



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0109985 **Received** : 19 Apr 2024
Lab Number : 06155258 **Tested** : 24 Apr 2024
Unique Number : 10990681 **Diagnosed** : 24 Apr 2024 - Sean Felton
Test Package : MOB 2 (Additional Tests: TBN)

DENNIS K BURKE INC - INTERNAL SAMPLES
 555 CONSTITUTION DR
 TAUNTON, MA
 US 02780
 Contact: GREG DUNKER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
 F: (617)889-6422