WEAR CONTAMINATION FLUID CONDITION


NORMAL NORMAL


PALEXTRA 44


INGERSOLL RAND PY3478U-10327 - LAKE COUNTY IH


Compressor


RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number	UOIVI	Client Info	LIIIII/ADII	UCS06156147	UCS05471448	
	Sample Date		Client Info		15 Apr 2024	08 Feb 2022	
	Machine Age	hrs	Client Info		17256	12250	
	Oil Age	hrs	Client Info		5000	6000	
	Filter Age	hrs	Client Info		3000	6000	
	Oil Changed	1110	Client Info		Changed	Changed	
	Filter Changed		Client Info		Changed	Changed	
	Sample Status				NORMAL	NORMAL	
WEAR	Iron	ppm	ASTM D5185m	>50	<1	0	
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>10	<1	0	
	Nickel	ppm	ASTM D5185m		<1	0	
	Titanium	ppm	ASTM D5185m		<1	0	
	Silver	ppm	ASTM D5185m		0	0	
	Aluminum	ppm	ASTM D5185m	>25	2	0	
	Lead	ppm	ASTM D5185m		0	0	
	Copper	ppm	ASTM D5185m	>50	<1	<1	
	Tin	ppm	ASTM D5185m	>15	<1	<1	
	Vanadium	ppm	ASTM D5185m		<1	0	
	White Metal	scalar	*Visual	NONE	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
CONTAMINATION	Silicon	nnm	ASTM D5185m	. 25	3	4	
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m		1	0	
	Water	ppm	WC Method		NEG	NEG	
	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	NONE	NONE	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
	Appearance	scalar	*Visual	NORML	NORML	NORML	
	Odor	scalar	*Visual	NORML	NORML	NORML	
	Emulsified Water		*Visual	>0.1	NEG	NEG	
FLUID CONDITION	Sodium	ppm	ASTM D5185m		<1	0	
	Boron	ppm	ASTM D5185m	0	0	<1	
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Barium	ppm	ASTM D5185m		<1	0	
	Molybdenum	ppm	ASTM D5185m		<1	0	
	Manganese	ppm	ASTM D5185m		0	0	
	Magnesium	ppm	ASTM D5185m	0.4	<1	0	
	Calcium	ppm	ASTM D5185m		<1	0	
	Phosphorus	ppm	ASTM D5185m	689	568	354	
	Zinc	ppm	ASTM D5185m		5	<1	
	Sulfur	ppm	ASTM D5185m	1237	274	163	
	Acid Number (AN)	mg KOH/g	ASTM D8045	0.135	0.21	0.15	
	Visc @ 40°C	cSt	ASTM D445	44.62	44.1	44.3	













Certificate L2367

Report Id: UCLIFSIO [WUSCAR] 06156147 (Generated: 04/24/2024 12:18:04) Rev: 1

Laboratory Sample No.

: UCS06156147 Lab Number : 06156147 Unique Number: 10991570 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received **Tested**

: 22 Apr 2024 : 23 Apr 2024

Diagnosed

: 24 Apr 2024 - Sean Felton

US 57104 Contact: REUBEN tim@liftproequipment.com T: (605)339-6494

SIOUX FALLS, SD

LIFT PRO EQUIPMENT CO

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: REUBEN - UCLIFSIO