



COOLANT REPORT

CORROSION	NORMAL
CONTAMINANTS	NORMAL
COOLANT CONDITION	NORMAL

Area
[PMOAS3340824]
 Machine Id
CUMMINS B6CB L010311602
 Component
Coolant
 Fluid
CONVENTIONAL COOLANT (--- GAL)

RECOMMENDATION

The fluid is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		DC0035394	DC0025311	DC0020414
Sample Date		Client Info		09 Apr 2024	24 Apr 2023	19 Apr 2022
Machine Age	hrs	Client Info		1068	1024	983
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	Changed	N/A
Sample Status				NORMAL	NORMAL	NORMAL








CORROSION

Total Dissolved Solids				192.5	179.5	201.5
Coolant Appearance		*Visual	Clear	normal	normal	normal

CONTAMINANTS

There is no indication of any contamination in the coolant.

Boiling Point	°C	WC Method		225	---	---
Specific Gravity		*ASTM D1298		1.067	1.069	1.068
pH	Scale 0-14	ASTM D1287		9.09	9.50	9.49
Nitrites	ppm	AP-053:2009		1652	1388	1428
Reserve Alkalinity	Scale 0-20	*ASTM D1121		---	---	---
Percentage Glycol	%	ASTM D3321		49.8	51.4	50.1
Freezing Point	°F	ASTM D3321		-33	-38	-35
Carboxylate				n/a	n/a	n/a
Coolant Color		*Visual		Purpl	Pink	Pink



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0035394
Lab Number : 06158236
Unique Number : 10993659
Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

KELLY GENERATOR & EQUIPMENT INC
 1955 DALE LN
 OWINGS, MD
 US 20736
 Contact: LESLIE SNURR
 LSNURR@KGE.COM
 T: (410)257-5225
 F: (410)257-5227

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)