CORROSION
CONTAMINANTS
COOLANT CONDITION

NORMAL NORMAL NORMAL


[PMOAS3340812]


KOHLER 150R002JF SGM329TJR

Component Coolant

CONVENTIONAL COOLANT (--- QTS)

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The fluid is suitable for further service.	Sample Number		Client Info		DC0035246	DC0027728	DC0020431
	Sample Date		Client Info		03 Apr 2024	12 Apr 2023	19 Apr 2022
	Machine Age	hrs	Client Info		234	0	0
	Oil Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		Not Changd	N/A	N/A
	Sample Status				NORMAL	NORMAL	NORMAL
CORROSION	Total Dissolved Solids				240.5	209.5	208.0
	Coolant Appearance		*Visual	Clear	normal	normal	normal
CONTAMINANTS	Boiling Point	°C	WC Method		226		
There is no indication of any contamination in the coolant.	Specific Gravity		*ASTM D1298		1.070	1.069	1.068
	рН	Scale 0-14	ASTM D1287		8.74	8.82	9.21
	Nitrites	ppm	AP-053:2009		1428	NT	1428
	Reserve Alkalinity	Scale 0-20	*ASTM D1121				
	Percentage Glycol	%	ASTM D3321		52.7	51.6	50.5
	Freezing Point	°F	ASTM D3321		-40	-38	-35
	Carboxylate				n/a	fail	n/a
	Coolant Color		*Visual		Purpl	Pink	Pink









Laboratory

Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Lab Number : 06158248 Unique Number : 10993671

: DC0035246

Received : 23 Apr 2024 **Tested** Diagnosed

: 25 Apr 2024 : 25 Apr 2024 - Jonathan Hester Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

KELLY GENERATOR & EQUIPMENT INC 1955 DALE LN OWINGS, MD

US 20736 Contact: LESLIE SNURR LSNURR@KGE.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (410)257-5225 F: (410)257-5227