

PALASYN 45 Machine Id PALATEK 19KE000634 - KOST MATERIALS Component Compressor

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		UCS06159219	UCS05879626	UCS05293130
	Sample Date		Client Info		09 Apr 2024	06 Jun 2023	16 Jun 2021
	Machine Age	hrs	Client Info		9559	7772	3577
	Oil Age	hrs	Client Info		0	4000	3577
	Filter Age	hrs	Client Info		0	4000	3577
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR	Iron	ppm	ASTM D5185m	>50	0	0	0
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>10	<1	0	0
	Nickel	ppm	ASTM D5185m		<1	0	0
	Titanium	ppm	ASTM D5185m		<1	0	0
	Silver	ppm	ASTM D5185m		0	0	0
	Aluminum	ppm	ASTM D5185m	>25	2	<1	0
	Lead	ppm	ASTM D5185m	>25	<1	0	0
	Copper	ppm	ASTM D5185m	>50	<1	<1	<1
	Tin	ppm	ASTM D5185m	>15	<1	0	0
	Vanadium	ppm	ASTM D5185m		<1	<1	0
	White Metal	scalar	*Visual	NONE	NONE	NONE	LIGHT
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
CONTAMINATION	Silicon	ppm	ASTM D5185m	>25	2	2	<1
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m	>20	<1	<1	<1
	Water		WC Method	>0.1	NEG	NEG	NEG
	Silt	scalar	*Visual	NONE	NONE	NONE	NONE
	Debris	scalar	*Visual	NONE	NONE	NONE	NONE
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
	Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
	Odor	scalar	*Visual	NORML	NORML	NORML	NORML
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	▲ 0.2%
FLUID CONDITION	Sodium	ppm	ASTM D5185m		4	<1	0
The AN level is acceptable for this fluid. The condition of the oil is	Boron	ppm	ASTM D5185m	0.0	0	0	<1
suitable for further service.	Barium	ppm	ASTM D5185m		0	0	0
	Molybdenum	ppm	ASTM D5185m	0	<1	0	0
	Manganese	ppm	ASTM D5185m	0	0	0	0
	Magnesium	ppm	ASTM D5185m	0.0	0	0	0
	Calcium	ppm	ASTM D5185m	0.0	3	0	0
	Phosphorus	ppm	ASTM D5185m	966	326	572	527
	Zinc	ppm	ASTM D5185m	0	7	0	0
	Sulfur	ppm	ASTM D5185m	1309	1111	1187	255

Acid Number (AN) mg KOH/g ASTM D8045 0.172

cSt


Visc @ 40°C

ASTM D445 39.9 44.8 42.4 40.2 Contact/Location: DALE K - UCJEMWES

0.09

0.079

0.065



JEMCO-MAXAIR Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. : UCS06159219 Received : 24 Apr 2024 Ĕ Lab Number : 06159219 Tested WEST FARGO, ND : 25 Apr 2024 Unique Number : 10994642 Diagnosed : 26 Apr 2024 - Jonathan Hester US 58078 Test Package : IND 2 Contact: DALE K Certificate L2367 dalek@jemco-maxair.com To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (701)281-0362 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: x:

Contact/Location: DALE K - UCJEMWES Page 2 of 2